

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway (244) - Pilot Test 11 Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP11-A	Hallway (16)	11/15/2019	11/19/2019	A9K0476-06	Lead	ND	0.20	15	ppb
244-CH-1088-A-PP11-A	Hallway (12)	11/15/2019	11/19/2019	A9K0476-07	Lead	ND	0.20	15	ppb
244-CH-1094-A-PP11-A	Cafeteria	11/15/2019	11/19/2019	A9K0476-08	Lead	1.35	0.20	15	ppb
244-CH-1096-A-PP11-A	Hallway (1)	11/15/2019	11/19/2019	A9K0476-09	Lead	0.282	0.20	15	ppb
244-CH-1098-A-PP11-A	Hallway (25)	11/15/2019	11/19/2019	A9K0476-10	Lead	1.16	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb