

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway (244) - Pilot Test 13 Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP13-A	Hallway (16)	12/20/2019	12/30/2019	A9L0895-06	Lead	ND	0.20	15	ppb
244-CH-1088-A-PP13-A	Hallway (12)	12/20/2019	12/30/2019	A9L0895-07	Lead	0.334	0.20	15	ppb
244-CH-1094-A-PP13-A	Cafeteria	12/20/2019	12/30/2019	A9L0895-08	Lead	0.826	0.20	15	ppb
244-CH-1096-A-PP13-A	Hallway (1)	12/20/2019	12/30/2019	A9L0895-09	Lead	ND	0.20	15	ppb
244-CH-1098-A-PP13-A	Hallway (25)	12/20/2019	12/30/2019	A9L0895-10	Lead	3.58	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb