

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway Elementary School (244) - Pilot Test 14 Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP14-A	Hallway (16)	1/10/2020	1/14/2020	A0A0276-06	Lead	ND	0.20	15	ppb
244-CH-1088-A-PP14-A	Hallway (12)	1/10/2020	1/14/2020	A0A0276-07	Lead	ND	0.20	15	ppb
244-CH-1094-A-PP14-A	Cafeteria	1/10/2020	1/14/2020	A0A0276-08	Lead	1.01	0.20	15	ppb
244-CH-1096-A-PP14-A	Hallway (1)	1/10/2020	1/14/2020	A0A0276-09	Lead	0.328	0.20	15	ppb
244-CH-1098-A-PP14-A	Hallway (25)	1/10/2020	1/14/2020	A0A0276-10	Lead	3.76	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb