

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway Elementary School (244) - Pilot Test 15 Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP15-A	Hallway (16)	1/24/2020	1/30/2020	A0A0877-06	Lead	ND	0.20	15	ppb
244-CH-1088-A-PP15-A	Hallway (12)	1/24/2020	1/30/2020	A0A0877-07	Lead	0.395	0.20	15	ppb
244-CH-1094-A-PP15-A	Cafeteria	1/24/2020	1/30/2020	A0A0877-08	Lead	1.54	0.20	15	ppb
244-CH-1096-A-PP15-A	Hallway (1)	1/24/2020	1/30/2020	A0A0877-09	Lead	0.355	0.20	15	ppb
244-CH-1098-A-PP15-A	Hallway (25)	1/24/2020	1/30/2020	A0A0877-10	Lead	3.16	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb