

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Duniway Elementary School (244) - Pilot Test 16 Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH-1068-A-PP16-A	Hallway (16)	2/7/2020	2/11/2020	A0B0204-06	Lead	ND	0.20	15	ppb
244-CH-1088-A-PP16-A	Hallway (12)	2/7/2020	2/11/2020	A0B0204-07	Lead	0.517	0.20	15	ppb
244-CH-1094-A-PP16-A	Cafeteria	2/7/2020	2/11/2020	A0B0204-08	Lead	1.43	0.20	15	ppb
244-CH-1096-A-PP16-A	Hallway (1)	2/7/2020	2/11/2020	A0B0204-09	Lead	0.324	0.20	15	ppb
244-CH-1098-A-PP16-A	Hallway (25)	2/7/2020	2/11/2020	A0B0204-10	Lead	3.72	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb