

**Portland Public Schools**  
**Pilot Program Lead Water Sampling Results**  
**Initial Flush Sample Data**  
**Jefferson High School - Week 2 Pilot Results**

| Sample Identification # | Location             | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|----------------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 118-CH-3606-A-PP02-A    | Hallway (A-7)        | 9/6/2019            | 9/11/2019     | A9I0145-46 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3606-B-PP02-A    | Hallway (A-7)        | 9/6/2019            | 9/11/2019     | A9I0145-47 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3616-A-PP02-A    | Hallway (A-47)       | 9/6/2019            | 9/11/2019     | A9I0145-48 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3616-B-PP02-A    | Hallway (A-47)       | 9/6/2019            | 9/11/2019     | A9I0145-49 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3616-C-PP02-A    | Hallway (A-47)       | 9/6/2019            | 9/11/2019     | A9I0145-50 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3628-A-PP02-A    | Cafeteria            | 9/6/2019            | 9/11/2019     | A9I0145-51 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3628-B-PP02-A    | Cafeteria            | 9/6/2019            | 9/11/2019     | A9I0145-52 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3628-C-PP02-A    | Cafeteria            | 9/6/2019            | 9/11/2019     | A9I0145-53 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3640-A-PP02-A    | Gym (North East End) | 9/6/2019            | 9/11/2019     | A9I0145-54 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3640-B-PP02-A    | Gym (North East End) | 9/6/2019            | 9/11/2019     | A9I0145-55 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3640-C-PP02-A    | Gym (North East End) | 9/6/2019            | 9/11/2019     | A9I0145-56 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3654-A-PP02-A    | Hallway (B-6)        | 9/6/2019            | 9/11/2019     | A9I0145-57 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3654-B-PP02-A    | Hallway (B-6)        | 9/6/2019            | 9/11/2019     | A9I0145-58 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3661-A-PP02-A    | Hallway (B-38)       | 9/6/2019            | 9/11/2019     | A9I0145-59 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3661-B-PP02-A    | Hallway (B-38)       | 9/6/2019            | 9/11/2019     | A9I0145-60 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3661-C-PP02-A    | Hallway (B-38)       | 9/6/2019            | 9/11/2019     | A9I0145-61 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3662-A-PP02-A    | Hallway (D-32)       | 9/6/2019            | 9/11/2019     | A9I0145-62 | Lead    | ND      | 0.20            | 15                | ppb   |

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb

|                      |                |          |           |            |      |    |      |    |     |
|----------------------|----------------|----------|-----------|------------|------|----|------|----|-----|
| 118-CH-3662-B-PP02-A | Hallway (D-32) | 9/6/2019 | 9/11/2019 | A9I0145-63 | Lead | ND | 0.20 | 15 | ppb |
| 118-CH-3662-C-PP02-A | Hallway (D-32) | 9/6/2019 | 9/11/2019 | A9I0145-64 | Lead | ND | 0.20 | 15 | ppb |
| 118-CH-3989-A-PP02-A | Hallway (C-40) | 9/6/2019 | 9/11/2019 | A9I0145-65 | Lead | ND | 0.20 | 15 | ppb |
| 118-CH-3989-B-PP02-A | Hallway (C-40) | 9/6/2019 | 9/11/2019 | A9I0145-66 | Lead | ND | 0.20 | 15 | ppb |
| 118-CH-3989-C-PP02-A | Hallway (C-40) | 9/6/2019 | 9/11/2019 | A9I0145-67 | Lead | ND | 0.20 | 15 | ppb |