

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Jefferson High School - Week 6 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-CH-3606-A-PP06-A	Hallway (A-7)	10/3/2019	10/9/2019	A9J0196-46	Lead	ND	0.20	15	ppb
118-CH-3606-B-PP06-A	Hallway (A-7)	10/3/2019	10/9/2019	A9J0196-47	Lead	ND	0.20	15	ppb
118-CH-3616-A-PP06-A	Hallway (A-47)	10/3/2019	10/9/2019	A9J0196-48	Lead	ND	0.20	15	ppb
118-CH-3616-B-PP06-A	Hallway (A-47)	10/3/2019	10/9/2019	A9J0196-49	Lead	0.258	0.20	15	ppb
118-CH-3616-C-PP06-A	Hallway (A-47)	10/3/2019	10/9/2019	A9J0196-50	Lead	ND	0.20	15	ppb
118-CH-3628-A-PP06-A	Cafeteria	10/3/2019	10/9/2019	A9J0196-51	Lead	ND	0.20	15	ppb
118-CH-3628-B-PP06-A	Cafeteria	10/3/2019	10/9/2019	A9J0196-52	Lead	ND	0.20	15	ppb
118-CH-3628-C-PP06-A	Cafeteria	10/3/2019	10/9/2019	A9J0196-53	Lead	ND	0.20	15	ppb
118-CH-3640-A-PP06-A	Gym (North East End)	10/3/2019	10/9/2019	A9J0196-54	Lead	ND	0.20	15	ppb
118-CH-3640-B-PP06-A	Gym (North East End)	10/3/2019	10/9/2019	A9J0196-55	Lead	ND	0.20	15	ppb
118-CH-3640-C-PP06-A	Gym (North East End)	10/3/2019	10/9/2019	A9J0196-56	Lead	ND	0.20	15	ppb
118-CH-3654-A-PP06-A	Hallway (B-6)	10/3/2019	10/9/2019	A9J0196-57	Lead	ND	0.20	15	ppb
118-CH-3654-B-PP06-A	Hallway (B-6)	10/3/2019	10/9/2019	A9J0196-58	Lead	ND	0.20	15	ppb
118-CH-3661-A-PP06-A	Hallway (B-38)	10/3/2019	10/9/2019	A9J0196-59	Lead	ND	0.20	15	ppb
118-CH-3661-B-PP06-A	Hallway (B-38)	10/3/2019	10/9/2019	A9J0196-60	Lead	ND	0.20	15	ppb
118-CH-3661-C-PP06-A	Hallway (B-38)	10/3/2019	10/9/2019	A9J0196-61	Lead	0.461	0.20	15	ppb
118-CH-3662-A-PP06-A	Hallway (D-32)	10/3/2019	10/9/2019	A9J0196-62	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

118-CH-3662-B-PP06-A	Hallway (D-32)	10/3/2019	10/9/2019	A9J0196-63	Lead	0.977	0.20	15	ppb
118-CH-3662-C-PP06-A	Hallway (D-32)	10/3/2019	10/9/2019	A9J0196-64	Lead	0.207	0.20	15	ppb
118-CH-3989-A-PP06-A	Hallway (C-40)	10/3/2019	10/9/2019	A9J0196-65	Lead	ND	0.20	15	ppb
118-CH-3989-B-PP06-A	Hallway (C-40)	10/3/2019	10/9/2019	A9J0196-66	Lead	ND	0.20	15	ppb
118-CH-3989-C-PP06-A	Hallway (C-40)	10/3/2019	10/9/2019	A9J0196-67	Lead	0.609	0.20	15	ppb