

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Jefferson High School - Week 7 Pilot Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-CH-3606-A-PP07-A	Hallway (A-7)	10/10/2019	10/16/2019	A9J0430-17	Lead	ND	0.20	15	ppb
118-CH-3616-A-PP07-A	Hallway (A-47)	10/10/2019	10/16/2019	A9J0430-18	Lead	ND	0.20	15	ppb
118-CH-3628-A-PP07-A	Cafeteria	10/10/2019	10/16/2019	A9J0430-19	Lead	ND	0.20	15	ppb
118-CH-3640-A-PP07-A	Gym (North East End)	10/10/2019	10/16/2019	A9J0430-20	Lead	ND	0.20	15	ppb
118-CH-3654-A-PP07-A	Hallway (B-6)	10/10/2019	10/16/2019	A9J0430-21	Lead	ND	0.20	15	ppb
118-CH-3661-A-PP07-A	Hallway (B-38)	10/10/2019	10/16/2019	A9J0430-22	Lead	ND	0.20	15	ppb
118-CH-3662-A-PP07-A	Hallway (D-32)	10/10/2019	10/16/2019	A9J0430-23	Lead	ND	0.20	15	ppb
118-CH-3989-A-PP07-A	Hallway (C-40)	10/10/2019	10/16/2019	A9J0430-24	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb