

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Jefferson High School - Week 8 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-CH-3606-A-PP08-A	Hallway (A-7)	10/17/2019	10/23/2019	A9J0747-17	Lead	ND	0.20	15	ppb
118-CH-3616-A-PP08-A	Hallway (A-47)	10/17/2019	10/23/2019	A9J0747-18	Lead	ND	0.20	15	ppb
118-CH-3628-A-PP08-A	Cafeteria	10/17/2019	10/23/2019	A9J0747-19	Lead	ND	0.20	15	ppb
118-CH-3640-A-PP08-A	Gym (North East End)	10/17/2019	10/23/2019	A9J0747-20RE1	Lead	ND	0.20	15	ppb
118-CH-3654-A-PP08-A	Hallway (B-6)	10/17/2019	10/23/2019	A9J0747-21RE1	Lead	ND	0.20	15	ppb
118-CH-3661-A-PP08-A	Hallway (B-38)	10/17/2019	10/23/2019	A9J0747-22RE1	Lead	ND	0.20	15	ppb
118-CH-3662-A-PP08-A	Hallway (D-32)	10/17/2019	10/23/2019	A9J0747-23RE1	Lead	ND	0.20	15	ppb
118-CH-3989-A-PP08-A	Hallway (C-40)	10/17/2019	10/23/2019	A9J0747-24RE1	Lead	ND	0.20	15	ppb
118-CH-3667-A-PP08-A	Hallway (C-4)	10/17/2019	10/23/2019	A9J0747-25RE1	Lead	ND	0.20	15	ppb
118-CH-3635-A-PP08-A	Dance Studio A	10/17/2019	10/23/2019	A9J0747-26RE2	Lead	ND	0.20	15	ppb
118-CH-3635-B-PP08-A	Dance Studio A	10/17/2019	10/23/2019	A9J0747-27RE1	Lead	ND	0.20	15	ppb
118-CH-3635-C-PP08-A	Dance Studio A	10/17/2019	10/23/2019	A9J0747-28RE1	Lead	0.288	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb