

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Jefferson High School - Test 11 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-CH-3606-A-PP11-A	Hallway (A-7)	11/14/2019	11/19/2019	A9K0476-17	Lead	ND	0.20	15	ppb
118-CH-3616-A-PP11-A	Hallway (A-47)	11/14/2019	11/19/2019	A9K0476-18	Lead	ND	0.20	15	ppb
118-CH-3628-A-PP11-A	Cafeteria	11/14/2019	11/19/2019	A9K0476-19	Lead	ND	0.20	15	ppb
118-CH-3640-A-PP11-A	Gym (North East End)	11/14/2019	11/19/2019	A9K0476-20	Lead	0.7	0.20	15	ppb
118-CH-3654-A-PP11-A	Hallway (B-6)	11/14/2019	11/19/2019	A9K0476-21	Lead	0.327	0.20	15	ppb
118-CH-3661-A-PP11-A	Hallway (B-38)	11/14/2019	11/19/2019	A9K0476-22	Lead	0.248	0.20	15	ppb
118-CH-3662-A-PP11-A	Hallway (D-32)	11/14/2019	11/19/2019	A9K0476-23	Lead	ND	0.20	15	ppb
118-CH-3989-A-PP11-A	Hallway (C-40)	11/14/2019	11/19/2019	A9K0476-24	Lead	0.31	0.20	15	ppb
118-CH-3667-A-PP11-A	Hallway (C-4)	11/14/2019	11/19/2019	A9K0476-25	Lead	ND	0.20	15	ppb
118-CH-3635-A-PP11-A	Dance Studio A	11/14/2019	11/19/2019	A9K0476-26	Lead	ND	0.20	15	ppb
118-CH-3634-A-PP11-A	Wresting Room	11/14/2019	11/19/2019	A9K0476-27	Lead	1.94	0.20	15	ppb
118-CH-3634-B-PP11-A	Wresting Room	11/14/2019	11/19/2019	A9K0476-28	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb