

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Jefferson High School - Test 12 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-CH-3606-A-PP12-A	Hallway (A-7)	12/5/2019	12/11/2019	A9L0186-17	Lead	ND	0.20	15	ppb
118-CH-3616-A-PP12-A	Hallway (A-47)	12/5/2019	12/11/2019	A9L0186-18	Lead	ND	0.20	15	ppb
118-CH-3628-A-PP12-A	Cafeteria	12/5/2019	12/11/2019	A9L0186-19	Lead	ND	0.20	15	ppb
118-CH-3640-A-PP12-A	Gym (North East End)	12/5/2019	12/11/2019	A9L0186-20	Lead	0.323	0.20	15	ppb
118-CH-3654-A-PP12-A	Hallway (B-6)	12/5/2019	12/11/2019	A9L0186-21	Lead	0.522	0.20	15	ppb
118-CH-3661-A-PP12-A	Hallway (B-38)	12/5/2019	12/11/2019	A9L0186-22	Lead	0.248	0.20	15	ppb
118-CH-3662-A-PP12-A	Hallway (D-32)	12/5/2019	12/11/2019	A9L0186-23	Lead	ND	0.20	15	ppb
118-CH-3989-A-PP12-A	Hallway (C-40)	12/5/2019	12/11/2019	A9L0186-24	Lead	0.502	0.20	15	ppb
118-CH-3667-A-PP12-A	Hallway (C-4)	12/5/2019	12/11/2019	A9L0186-25	Lead	ND	0.20	15	ppb
118-CH-3635-A-PP12-A	Dance Studio A	12/5/2019	12/11/2019	A9L0186-26	Lead	ND	0.20	15	ppb
118-CH-3634-A-PP12-A	Wresting Room	12/5/2019	12/11/2019	A9L0186-27	Lead	0.514	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb