

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Jefferson High School - Test 13 Pilot Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-CH-3606-A-PP13-A	Hallway (A-7)	12/19/2019	12/30/2019	A9L0895-17	Lead	ND	0.20	15	ppb
118-CH-3616-A-PP13-A	Hallway (A-47)	12/19/2019	12/30/2019	A9L0895-18	Lead	0.203	0.20	15	ppb
118-CH-3628-A-PP13-A	Cafeteria	12/19/2019	12/30/2019	A9L0895-19	Lead	ND	0.20	15	ppb
118-CH-3640-A-PP13-A	Gym (North East End)	12/19/2019	12/30/2019	A9L0895-20	Lead	1.65	0.20	15	ppb
118-CH-3654-A-PP13-A	Hallway (B-6)	12/19/2019	12/30/2019	A9L0895-21	Lead	0.576	0.20	15	ppb
118-CH-3661-A-PP13-A	Hallway (B-38)	12/19/2019	12/30/2019	A9L0895-22	Lead	0.264	0.20	15	ppb
118-CH-3662-A-PP13-A	Hallway (D-32)	12/19/2019	12/30/2019	A9L0895-23	Lead	ND	0.20	15	ppb
118-CH-3989-A-PP13-A	Hallway (C-40)	12/19/2019	12/30/2019	A9L0895-24	Lead	0.383	0.20	15	ppb
118-CH-3667-A-PP13-A	Hallway (C-4)	12/19/2019	12/30/2019	A9L0895-25	Lead	ND	0.20	15	ppb
118-CH-3635-A-PP13-A	Dance Studio A	12/19/2019	12/30/2019	A9L0895-26	Lead	ND	0.20	15	ppb
118-CH-3634-A-PP13-A	Wresting Room	12/19/2019	12/30/2019	A9L0895-27	Lead	0.474	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb