

**Portland Public Schools**  
**Pilot Program Lead Water Sampling Results**  
**Initial Flush Sample Data**  
**Jefferson High School - Test 14 Pilot Results**

| Sample Identification # | Location             | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|----------------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 118-CH-3606-A-PP14-A    | Hallway (A-7)        | 1/9/2020            | 1/13/2020     | A0A0276-17 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3616-A-PP14-A    | Hallway (A-47)       | 1/9/2020            | 1/13/2020     | A0A0276-18 | Lead    | 0.356   | 0.20            | 15                | ppb   |
| 118-CH-3628-A-PP14-A    | Cafeteria            | 1/9/2020            | 1/13/2020     | A0A0276-19 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3640-A-PP14-A    | Gym (North East End) | 1/9/2020            | 1/13/2020     | A0A0276-20 | Lead    | 0.599   | 0.20            | 15                | ppb   |
| 118-CH-3654-A-PP14-A    | Hallway (B-6)        | 1/9/2020            | 1/13/2020     | A0A0276-21 | Lead    | 0.696   | 0.20            | 15                | ppb   |
| 118-CH-3661-A-PP14-A    | Hallway (B-38)       | 1/9/2020            | 1/13/2020     | A0A0276-22 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3662-A-PP14-A    | Hallway (D-32)       | 1/9/2020            | 1/13/2020     | A0A0276-23 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3989-A-PP14-A    | Hallway (C-40)       | 1/9/2020            | 1/13/2020     | A0A0276-24 | Lead    | 0.258   | 0.20            | 15                | ppb   |
| 118-CH-3667-A-PP14-A    | Hallway (C-4)        | 1/9/2020            | 1/13/2020     | A0A0276-25 | Lead    | ND      | 0.20            | 15                | ppb   |
| 118-CH-3635-A-PP14-A    | Dance Studio A       | 1/9/2020            | 1/13/2020     | A0A0276-26 | Lead    | ND      | 0.20            | 15                | ppb   |

Analyzed by: Apex Laboratories  
Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb