

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Jefferson High School - Test 15 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-CH-3606-A-PP15-A	Hallway (A-7)	1/24/2020	1/30/2020	A0A0877-17	Lead	ND	0.20	15	ppb
118-CH-3616-A-PP15-A	Hallway (A-47)	1/24/2020	1/30/2020	A0A0877-18	Lead	0.289	0.20	15	ppb
118-CH-3628-A-PP15-A	Cafeteria	1/24/2020	1/30/2020	A0A0877-19	Lead	ND	0.20	15	ppb
118-CH-3640-A-PP15-A	Gym (North East End)	1/24/2020	1/30/2020	A0A0877-20	Lead	0.872	0.20	15	ppb
118-CH-3654-A-PP15-A	Hallway (B-6)	1/24/2020	1/30/2020	A0A0877-21	Lead	0.573	0.20	15	ppb
118-CH-3661-A-PP15-A	Hallway (B-38)	1/24/2020	1/30/2020	A0A0877-22	Lead	ND	0.20	15	ppb
118-CH-3662-A-PP15-A	Hallway (D-32)	1/24/2020	1/30/2020	A0A0877-23	Lead	ND	0.20	15	ppb
118-CH-3989-A-PP15-A	Hallway (C-40)	1/24/2020	1/30/2020	A0A0877-24	Lead	0.352	0.20	15	ppb
118-CH-3667-A-PP15-A	Hallway (C-4)	1/24/2020	1/30/2020	A0A0877-25	Lead	0.285	0.20	15	ppb
118-CH-3635-A-PP15-A	Dance Studio A	1/24/2020	1/30/2020	A0A0877-26	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb