

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Jefferson High School - Test 17 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-CH-3606-A-PP17-A	Hallway (A-7)	2/20/2020	2/27/2020	A0B0574-17	Lead	ND	0.20	15	ppb
118-CH-3616-A-PP17-A	Hallway (A-47)	2/20/2020	2/27/2020	A0B0574-18	Lead	0.393	0.20	15	ppb
118-CH-3628-A-PP17-A	Cafeteria	2/20/2020	2/27/2020	A0B0574-19	Lead	ND	0.20	15	ppb
118-CH-3640-A-PP17-A	Gym (North East End)	2/20/2020	2/27/2020	A0B0574-20	Lead	0.893	0.20	15	ppb
118-CH-3654-A-PP17-A	Hallway (B-6)	2/20/2020	2/27/2020	A0B0574-21	Lead	0.396	0.20	15	ppb
118-CH-3661-A-PP17-A	Hallway (B-38)	2/20/2020	2/27/2020	A0B0574-22	Lead	ND	0.20	15	ppb
118-CH-3662-A-PP17-A	Hallway (D-32)	2/20/2020	2/27/2020	A0B0574-23	Lead	ND	0.20	15	ppb
118-CH-3989-A-PP17-A	Hallway (C-40)	2/20/2020	2/27/2020	A0B0574-24	Lead	0.317	0.20	15	ppb
118-CH-3667-A-PP17-A	Hallway (C-4)	2/20/2020	2/27/2020	A0B0574-25	Lead	ND	0.20	15	ppb
118-CH-3635-A-PP17-A	Dance Studio A	2/20/2020	2/27/2020	A0B0574-26	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb