

**Portland Public Schools
Pilot Program - Lead Water Sampling Results
Initial Flush Sample Data
Llewelyn (269) - Test PP01 - Week 1**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-CH-1278-A-PP01-A	Hallway (206)	8/19/2019	8/21/2019	A9H0599-01	Lead	ND	0.20	15	ppb
269-CH-1278-B-PP01-A	Hallway (206)	8/19/2019	8/21/2019	A9H0599-02	Lead	ND	0.20	15	ppb
269-CH-1278-C-PP01-A	Hallway (206)	8/19/2019	8/21/2019	A9H0599-03	Lead	ND	0.20	15	ppb
269-CH-1280-A-PP01-A	Hallway (108)	8/19/2019	8/21/2019	A9H0599-04	Lead	ND	0.20	15	ppb
269-CH-1280-B-PP01-A	Hallway (108)	8/19/2019	8/21/2019	A9H0599-05	Lead	ND	0.20	15	ppb
269-CH-1280-C-PP01-A	Hallway (108)	8/19/2019	8/21/2019	A9H0599-06	Lead	ND	0.20	15	ppb
269-CH-1279-A-PP01-A	Hallway (205)	8/19/2019	8/21/2019	A9H0599-07	Lead	0.391	0.20	15	ppb
269-CH-1279-B-PP01-A	Hallway (205)	8/19/2019	8/21/2019	A9H0599-08	Lead	ND	0.20	15	ppb
269-CH-1279-C-PP01-A	Hallway (205)	8/19/2019	8/21/2019	A9H0599-09	Lead	0.333	0.20	15	ppb