

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Llewellyn (269) - Week 2 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-CH-1278-A-PP02-A	Hallway (206)	9/6/2019	9/11/2019	A9I0145-68	Lead	0.247	0.20	15	ppb
269-CH-1278-B-PP02-A	Hallway (206)	9/6/2019	9/11/2019	A9I0145-69	Lead	ND	0.20	15	ppb
269-CH-1278-C-PP02-A	Hallway (206)	9/6/2019	9/11/2019	A9I0145-70	Lead	ND	0.20	15	ppb
269-CH-1279-A-PP02-A	Hallway (205)	9/6/2019	9/11/2019	A9I0145-71	Lead	ND	0.20	15	ppb
269-CH-1279-B-PP02-A	Hallway (205)	9/6/2019	9/11/2019	A9I0145-72	Lead	ND	0.20	15	ppb
269-CH-1279-C-PP02-A	Hallway (205)	9/6/2019	9/11/2019	A9I0145-73	Lead	ND	0.20	15	ppb
269-CH-1280-A-PP02-A	Hallway (108)	9/6/2019	9/11/2019	A9I0145-74	Lead	ND	0.20	15	ppb
269-CH-1280-B-PP02-A	Hallway (108)	9/6/2019	9/11/2019	A9I0145-75	Lead	ND	0.20	15	ppb
269-CH-1280-C-PP02-A	Hallway (108)	9/6/2019	9/11/2019	A9I0145-76	Lead	ND	0.20	15	ppb
269-CH-1277-A-PP03-A	Hallway (Cafeteria)	9/10/2019	9/11/2019	A9I0288-01	Lead	0.678	0.20	15	ppb
269-CH-1277-B-PP03-A	Hallway (Cafeteria)	9/10/2019	9/11/2019	A9I0288-02	Lead	ND	0.20	15	ppb
269-CH-1277-C-PP03-A	Hallway (Cafeteria)	9/10/2019	9/11/2019	A9I0288-03	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb