

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Llewellyn (269) - Week 8 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-CH-1278-A-PP08-A	Hallway (206)	10/18/2019	10/23/2019	A9J0747-29RE1	Lead	ND	0.20	15	ppb
269-CH-1279-A-PP08-A	Hallway (205)	10/18/2019	10/23/2019	A9J0747-30RE1	Lead	ND	0.20	15	ppb
269-CH-1280-A-PP08-A	Hallway (108)	10/18/2019	10/23/2019	A9J0747-31RE1	Lead	ND	0.20	15	ppb
269-CH-1277-A-PP08-A	Hallway (Cafeteria)	10/18/2019	10/23/2019	A9J0747-32RE1	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb