

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Llewellyn (269) - Test 12 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-CH-1278-A-PP12-A	Hallway (206)	12/6/2019	12/11/2019	A9L0186-28	Lead	0.257	0.20	15	ppb
269-CH-1279-A-PP12-A	Hallway (205)	12/6/2019	12/11/2019	A9L0186-29	Lead	ND	0.20	15	ppb
269-CH-1280-A-PP12-A	Hallway (108)	12/6/2019	12/11/2019	A9L0186-30	Lead	0.278	0.20	15	ppb
269-CH-1277-A-PP12-A	Hallway (Cafeteria)	12/6/2019	12/11/2019	A9L0186-31	Lead	0.357	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb