

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Llewellyn Elementary School (269) - Test 15 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-CH-1278-A-PP15-A	Hallway (206)	1/24/2020	1/30/2020	A0A0877-27	Lead	0.309	0.20	15	ppb
269-CH-1279-A-PP15-A	Hallway (205)	1/24/2020	1/30/2020	A0A0877-28	Lead	ND	0.20	15	ppb
269-CH-1280-A-PP15-A	Hallway (108)	1/24/2020	1/30/2020	A0A0877-29	Lead	0.472	0.20	15	ppb
269-CH-1277-A-PP15-A	Hallway (Cafeteria)	1/24/2020	1/30/2020	A0A0877-30	Lead	0.432	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb