

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Llewellyn Elementary School (269) - Test 18 Pilot Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-CH-1278-A-PP18-A	Hallway (206)	3/6/2020	3/11/2020	A0C0231-27	Lead	ND	0.20	15	ppb
269-CH-1279-A-PP18-A	Hallway (205)	3/6/2020	3/11/2020	A0C0231-28	Lead	0.29	0.20	15	ppb
269-CH-1280-A-PP18-A	Hallway (108)	3/6/2020	3/11/2020	A0C0231-29	Lead	0.415	0.20	15	ppb
269-CH-1277-A-PP18-A	Hallway (Cafeteria)	3/6/2020	3/11/2020	A0C0231-30	Lead	0.657	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb