

**Portland Public Schools
Lead Water Sampling Results
Initial Filter Installation-Flush Sample Data
Rigler Elementary School - Pilot Test 1**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
276-CH-1634-A-PP01-A	Hallway (34)	10/8/2019	10/9/2019	A9J0244-01	Lead	ND	0.20	15	ppb
276-CH-1634-B-PP01-A	Hallway (34)	10/8/2019	10/9/2019	A9J0244-02	Lead	0.262	0.20	15	ppb
276-CH-1634-C-PP01-A	Hallway (34)	10/8/2019	10/9/2019	A9J0244-03	Lead	ND	0.20	15	ppb
276-CH-1643-A-PP01-A	Hallway (21F)	10/8/2019	10/9/2019	A9J0244-04	Lead	ND	0.20	15	ppb
276-CH-1643-B-PP01-A	Hallway (21F)	10/8/2019	10/9/2019	A9J0244-05	Lead	ND	0.20	15	ppb
276-CH-1643-C-PP01-A	Hallway (21F)	10/8/2019	10/9/2019	A9J0244-06	Lead	ND	0.20	15	ppb
276-CH-1733-A-PP01-A	Hallway (27A)	10/8/2019	10/9/2019	A9J0244-07	Lead	ND	0.20	15	ppb
276-CH-1733-B-PP01-A	Hallway (27A)	10/8/2019	10/9/2019	A9J0244-08	Lead	ND	0.20	15	ppb
276-CH-1733-C-PP01-A	Hallway (27A)	10/8/2019	10/9/2019	A9J0244-09	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb