

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Rigler Elementary School (276) - Pilot Test Week 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
276-CH-1634-A-PP03-A	Hallway (34)	10/18/2019	10/23/2019	A9J0747-33RE1	Lead	ND	0.20	15	ppb
276-CH-1634-B-PP03-A	Hallway (34)	10/18/2019	10/23/2019	A9J0747-34RE1	Lead	ND	0.20	15	ppb
276-CH-1634-C-PP03-A	Hallway (34)	10/18/2019	10/23/2019	A9J0747-35RE1	Lead	ND	0.20	15	ppb
276-CH-1643-A-PP03-A	Hallway (21F)	10/18/2019	10/23/2019	A9J0747-36RE1	Lead	ND	0.20	15	ppb
276-CH-1643-B-PP03-A	Hallway (21F)	10/18/2019	10/23/2019	A9J0747-37RE1	Lead	ND	0.20	15	ppb
276-CH-1643-C-PP03-A	Hallway (21F)	10/18/2019	10/23/2019	A9J0747-38RE1	Lead	ND	0.20	15	ppb
276-CH-1733-A-PP03-A	Hallway (27A)	10/18/2019	10/23/2019	A9J0747-39RE1	Lead	ND	0.20	15	ppb
276-CH-1733-B-PP03-A	Hallway (27A)	10/18/2019	10/23/2019	A9J0747-40RE1	Lead	ND	0.20	15	ppb
276-CH-1733-C-PP03-A	Hallway (27A)	10/18/2019	10/23/2019	A9J0747-41RE1	Lead	ND	0.20	15	ppb
276-CH-1631-A-PP03-A	Hallway (Cafeteria)	10/17/2019	10/18/2019	A9J0696-01	Lead	ND	0.20	15	ppb
276-CH-1631-B-PP03-A	Hallway (Cafeteria)	10/17/2019	10/18/2019	A9J0696-02	Lead	ND	0.20	15	ppb
276-CH-1631-C-PP03-A	Hallway (Cafeteria)	10/17/2019	10/18/2019	A9J0696-03	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb