

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Rigler Elementary School (276) - Pilot Test 6 Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
276-CH-1634-A-PP06-A	Hallway (34)	11/8/2019	11/13/2019	A9K0220-01	Lead	0.265	0.20	15	ppb
276-CH-1634-B-PP06-A	Hallway (34)	11/8/2019	11/13/2019	A9K0220-02RE1	Lead	ND	0.20	15	ppb
276-CH-1634-C-PP06-A	Hallway (34)	11/8/2019	11/13/2019	A9K0220-03	Lead	ND	0.20	15	ppb
276-CH-1643-A-PP06-A	Hallway (21F)	11/8/2019	11/13/2019	A9K0220-04	Lead	ND	0.20	15	ppb
276-CH-1643-B-PP06-A	Hallway (21F)	11/8/2019	11/13/2019	A9K0220-05	Lead	ND	0.20	15	ppb
276-CH-1643-C-PP06-A	Hallway (21F)	11/8/2019	11/13/2019	A9K0220-06	Lead	ND	0.20	15	ppb
276-CH-1733-A-PP06-A	Hallway (27A)	11/8/2019	11/13/2019	A9K0220-07	Lead	ND	0.20	15	ppb
276-CH-1733-B-PP06-A	Hallway (27A)	11/8/2019	11/13/2019	A9K0220-08	Lead	ND	0.20	15	ppb
276-CH-1733-C-PP06-A	Hallway (27A)	11/8/2019	11/13/2019	A9K0220-09	Lead	ND	0.20	15	ppb
276-CH-1631-A-PP06-A	Hallway (Cafeteria)	11/8/2019	11/13/2019	A9K0220-10	Lead	ND	0.20	15	ppb
276-CH-1631-B-PP06-A	Hallway (Cafeteria)	11/8/2019	11/13/2019	A9K0220-11RE1	Lead	0.333	0.20	15	ppb
276-CH-1631-C-PP06-A	Hallway (Cafeteria)	11/8/2019	11/13/2019	A9K0220-12	Lead	0.482	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb