

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Rigler Elementary School (276) - Pilot Test 8 Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
276-CH-1634-A-PP08-A	Hallway (34)	11/22/2019	11/26/2019	A9K0708-01RE1	Lead	ND	0.20	15	ppb
276-CH-1634-B-PP08-A	Hallway (34)	11/22/2019	11/26/2019	A9K0708-02RE1	Lead	ND	0.20	15	ppb
276-CH-1634-C-PP08-A	Hallway (34)	11/22/2019	11/26/2019	A9K0708-03RE1	Lead	ND	0.20	15	ppb
276-CH-1643-A-PP08-A	Hallway (21F)	11/22/2019	11/26/2019	A9K0708-04RE1	Lead	0.576	0.20	15	ppb
276-CH-1643-B-PP08-A	Hallway (21F)	11/22/2019	11/26/2019	A9K0708-05RE1	Lead	ND	0.20	15	ppb
276-CH-1643-C-PP08-A	Hallway (21F)	11/22/2019	11/26/2019	A9K0708-06RE1	Lead	0.884	0.20	15	ppb
276-CH-1733-A-PP08-A	Hallway (27A)	11/22/2019	11/26/2019	A9K0708-07RE1	Lead	ND	0.20	15	ppb
276-CH-1733-B-PP08-A	Hallway (27A)	11/22/2019	11/26/2019	A9K0708-08RE1	Lead	ND	0.20	15	ppb
276-CH-1733-C-PP08-A	Hallway (27A)	11/22/2019	11/26/2019	A9K0708-09RE1	Lead	ND	0.20	15	ppb
276-CH-1631-A-PP08-A	Hallway (Cafeteria)	11/22/2019	11/26/2019	A9K0708-10RE1	Lead	ND	0.20	15	ppb
276-CH-1631-B-PP08-A	Hallway (Cafeteria)	11/22/2019	11/26/2019	A9K0708-11	Lead	ND	0.20	15	ppb
276-CH-1631-C-PP08-A	Hallway (Cafeteria)	11/22/2019	11/26/2019	A9K0708-12	Lead	2.08	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb