

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Rigler Elementary School (276) - Pilot Test 9 Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
276-CH-1634-A-PP09-A	Hallway (34)	12/5/2019	12/11/2019	A9L0186-32	Lead	ND	0.20	15	ppb
276-CH-1643-A-PP09-A	Hallway (21F)	12/5/2019	12/11/2019	A9L0186-33	Lead	ND	0.20	15	ppb
276-CH-1733-A-PP09-A	Hallway (27A)	12/5/2019	12/11/2019	A9L0186-34	Lead	ND	0.20	15	ppb
276-CH-1631-A-PP09-A	Hallway (Cafeteria)	12/5/2019	12/11/2019	A9L0186-35	Lead	0.314	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb