

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Rigler Elementary School (276) - Pilot Test 11 Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
276-CH-1634-A-PP11-A	Hallway (34)	1/9/2020	1/14/2020	A0A0276-31	Lead	ND	0.20	15	ppb
276-CH-1643-A-PP11-A	Hallway (21F)	1/9/2020	1/14/2020	A0A0276-32	Lead	0.689	0.20	15	ppb
276-CH-1733-A-PP11-A	Hallway (27A)	1/9/2020	1/14/2020	A0A0276-33	Lead	ND	0.20	15	ppb
276-CH-1631-A-PP11-A	Hallway (Cafeteria)	1/9/2020	1/14/2020	A0A0276-34	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb