

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Gray Middle School (158) - Test PP01 - Week 1

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
158-CH-4405-A-PP01-A	Hallway 100	8/21/2019	8/23/2019	A9H0692-12	Lead	ND	0.20	15	ppb
158-CH-4405-B-PP01-A	Hallway 100	8/21/2019	8/23/2019	A9H0692-13	Lead	ND	0.20	15	ppb
158-CH-4405-C-PP01-A	Hallway 100	8/21/2019	8/23/2019	A9H0692-14	Lead	ND	0.20	15	ppb
158-CH-4449-A-PP01-A	Hallway 207	8/21/2019	8/23/2019	A9H0692-15	Lead	0.254	0.20	15	ppb
158-CH-4449-B-PP01-A	Hallway 207	8/21/2019	8/23/2019	A9H0692-16	Lead	ND	0.20	15	ppb
158-CH-4449-C-PP01-A	Hallway 207	8/21/2019	8/23/2019	A9H0692-17	Lead	ND	0.20	15	ppb
158-CH-4443-A-PP01-A	Hallway 124	8/21/2019	8/23/2019	A9H0692-18	Lead	ND	0.20	15	ppb
158-CH-4443-B-PP01-A	Hallway 124	8/21/2019	8/23/2019	A9H0692-19	Lead	ND	0.20	15	ppb
158-CH-4443-C-PP01-A	Hallway 124	8/21/2019	8/23/2019	A9H0692-20	Lead	ND	0.20	15	ppb
158-CH-4417-A-PP01-A	Hallway 111	8/21/2019	8/23/2019	A9H0692-21	Lead	ND	0.20	15	ppb
158-CH-4417-B-PP01-A	Hallway 111	8/21/2019	8/23/2019	A9H0692-22	Lead	ND	0.20	15	ppb
158-CH-4417-C-PP01-A	Hallway 111	8/21/2019	8/23/2019	A9H0692-23	Lead	ND	0.20	15	ppb
158-CH-4424-A-PP01-A	Hallway (Boiler Rm)	8/21/2019	8/23/2019	A9H0692-24	Lead	ND	0.20	15	ppb
158-CH-4424-B-PP01-A	Hallway (Boiler Rm)	8/21/2019	8/23/2019	A9H0692-25	Lead	ND	0.20	15	ppb
158-CH-4424-C-PP01-A	Hallway (Boiler Rm)	8/21/2019	8/23/2019	A9H0692-26	Lead	ND	0.20	15	ppb
158-CH-4414-A-PP01-A	Hallway 98	8/21/2019	8/23/2019	A9H0692-27	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

158-CH-4414-B-PP01-A	Hallway 98	8/21/2019	8/23/2019	A9H0692-28	Lead	ND	0.20	15	ppb
158-CH-4414-C-PP01-A	Hallway 99	8/21/2019	8/23/2019	A9H0692-29	Lead	ND	0.20	15	ppb