

**Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Gray Middle School - Week 4 Pilot Results**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
158-CH-4405-A-PP04-A	Hallway (100)	9/20/2019	9/24/2019	A9I0648-28	Lead	ND	0.20	15	ppb
158-CH-4405-B-PP04-A	Hallway (100)	9/20/2019	9/24/2019	A9I0648-29	Lead	ND	0.20	15	ppb
158-CH-4405-C-PP04-A	Hallway (100)	9/20/2019	9/24/2019	A9I0648-30	Lead	ND	0.20	15	ppb
158-CH-4414-A-PP04-A	Hallway (98)	9/20/2019	9/24/2019	A9I0648-31	Lead	ND	0.20	15	ppb
158-CH-4414-B-PP04-A	Hallway (98)	9/20/2019	9/24/2019	A9I0648-32	Lead	ND	0.20	15	ppb
158-CH-4414-C-PP04-A	Hallway (98)	9/20/2019	9/24/2019	A9I0648-33	Lead	ND	0.20	15	ppb
158-CH-4417-A-PP04-A	Hallway (111)	9/20/2019	9/24/2019	A9I0648-34	Lead	ND	0.20	15	ppb
158-CH-4417-B-PP04-A	Hallway (111)	9/20/2019	9/24/2019	A9I0648-35	Lead	ND	0.20	15	ppb
158-CH-4417-C-PP04-A	Hallway (111)	9/20/2019	9/24/2019	A9I0648-36	Lead	ND	0.20	15	ppb
158-CH-4424-A-PP04-A	Hallway (Boiler Rm)	9/20/2019	9/24/2019	A9I0648-37	Lead	ND	0.20	15	ppb
158-CH-4424-B-PP04-A	Hallway (Boiler Rm)	9/20/2019	9/24/2019	A9I0648-38	Lead	ND	0.20	15	ppb
158-CH-4424-C-PP04-A	Hallway (Boiler Rm)	9/20/2019	9/24/2019	A9I0648-39	Lead	ND	0.20	15	ppb
158-CH-4443-A-PP04-A	Hallway (124)	9/20/2019	9/24/2019	A9I0648-40	Lead	ND	0.20	15	ppb
158-CH-4443-B-PP04-A	Hallway (124)	9/20/2019	9/24/2019	A9I0648-41	Lead	ND	0.20	15	ppb
158-CH-4443-C-PP04-A	Hallway (124)	9/20/2019	9/24/2019	A9I0648-42	Lead	ND	0.20	15	ppb
158-CH-4449-A-PP04-A	Hallway (207)	9/20/2019	9/24/2019	A9I0648-43	Lead	ND	0.20	15	ppb
158-CH-4449-B-PP04-A	Hallway (207)	9/20/2019	9/24/2019	A9I0648-44	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

158-CH-4449-C-PP04-A	Hallway (207)	9/20/2019	9/24/2019	A9I0648-45	Lead	ND	0.20	15	ppb
----------------------	---------------	-----------	-----------	------------	------	----	------	----	-----

*OHA Action Level = 15ppb