

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Gray Middle School - Week 5 Pilot Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
158-CH-4405-A-PP05-A	Hallway (100)	9/27/2019	9/30/2019	A9I0909-28	Lead	ND	0.20	15	ppb
158-CH-4405-B-PP05-A	Hallway (100)	9/27/2019	9/30/2019	A9I0909-29	Lead	ND	0.20	15	ppb
158-CH-4405-C-PP05-A	Hallway (100)	9/27/2019	9/30/2019	A9I0909-30	Lead	0.303	0.20	15	ppb
158-CH-4414-A-PP05-A	Hallway (98)	9/27/2019	9/30/2019	A9I0909-31	Lead	ND	0.20	15	ppb
158-CH-4414-B-PP05-A	Hallway (98)	9/27/2019	9/30/2019	A9I0909-32	Lead	ND	0.20	15	ppb
158-CH-4414-C-PP05-A	Hallway (98)	9/27/2019	9/30/2019	A9I0909-33	Lead	ND	0.20	15	ppb
158-CH-4417-A-PP05-A	Hallway (111)	9/27/2019	9/30/2019	A9I0909-34	Lead	ND	0.20	15	ppb
158-CH-4417-B-PP05-A	Hallway (111)	9/27/2019	9/30/2019	A9I0909-35	Lead	ND	0.20	15	ppb
158-CH-4417-C-PP05-A	Hallway (111)	9/27/2019	9/30/2019	A9I0909-36	Lead	ND	0.20	15	ppb
158-CH-4424-A-PP05-A	Hallway (Boiler Rm)	9/27/2019	9/30/2019	A9I0909-37	Lead	ND	0.20	15	ppb
158-CH-4424-B-PP05-A	Hallway (Boiler Rm)	9/27/2019	9/30/2019	A9I0909-38	Lead	ND	0.20	15	ppb
158-CH-4424-C-PP05-A	Hallway (Boiler Rm)	9/27/2019	9/30/2019	A9I0909-39	Lead	ND	0.20	15	ppb
158-CH-4443-A-PP05-A	Hallway (124)	9/27/2019	9/30/2019	A9I0909-40	Lead	ND	0.20	15	ppb
158-CH-4443-B-PP05-A	Hallway (124)	9/27/2019	9/30/2019	A9I0909-41	Lead	ND	0.20	15	ppb
158-CH-4443-C-PP05-A	Hallway (124)	9/27/2019	9/30/2019	A9I0909-42	Lead	ND	0.20	15	ppb
158-CH-4449-A-PP05-A	Hallway (207)	9/27/2019	9/30/2019	A9I0909-43	Lead	ND	0.20	15	ppb
158-CH-4449-B-PP05-A	Hallway (207)	9/27/2019	9/30/2019	A9I0909-44	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

158-CH-4449-C-PP05-A	Hallway (207)	9/27/2019	9/30/2019	A9I0909-45	Lead	ND	0.20	15	ppb
----------------------	---------------	-----------	-----------	------------	------	----	------	----	-----

*OHA Action Level = 15ppb