

**Portland Public Schools  
Pilot Program Lead Water Sampling Results  
Initial Flush Sample Data  
Gray Middle School - Test 10 Pilot Results**

| Sample Identification # | Location            | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|---------------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 158-CH-4405-A-PP10-A    | Hallway (100)       | 11/1/2019           | 11/5/2019     | A9K0001-11 | Lead    | ND      | 0.20            | 15                | ppb   |
| 158-CH-4414-A-PP10-A    | Hallway (98)        | 11/1/2019           | 11/5/2019     | A9K0001-12 | Lead    | ND      | 0.20            | 15                | ppb   |
| 158-CH-4417-A-PP10-A    | Hallway (111)       | 11/1/2019           | 11/5/2019     | A9K0001-13 | Lead    | ND      | 0.20            | 15                | ppb   |
| 158-CH-4424-A-PP10-A    | Hallway (Boiler Rm) | 11/1/2019           | 11/5/2019     | A9K0001-14 | Lead    | ND      | 0.20            | 15                | ppb   |
| 158-CH-4443-A-PP10-A    | Hallway (124)       | 11/1/2019           | 11/5/2019     | A9K0001-15 | Lead    | ND      | 0.20            | 15                | ppb   |
| 158-CH-4449-A-PP10-A    | Hallway (207)       | 11/1/2019           | 11/5/2019     | A9K0001-16 | Lead    | ND      | 0.20            | 15                | ppb   |

Analyzed by: Apex Laboratories  
Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb