

Portland Public Schools
Pilot Program Lead Water Sampling Results
Initial Flush Sample Data
Gray Middle School - Test 14 Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
158-CH-4405-A-PP14-A	Hallway (100)	1/10/2020	1/14/2020	A0A0276-11	Lead	ND	0.20	15	ppb
158-CH-4414-A-PP14-A	Hallway (98)	1/10/2020	1/14/2020	A0A0276-12	Lead	ND	0.20	15	ppb
158-CH-4417-A-PP14-A	Hallway (111)	1/10/2020	1/14/2020	A0A0276-13	Lead	ND	0.20	15	ppb
158-CH-4424-A-PP14-A	Hallway (Boiler Rm)	1/10/2020	1/14/2020	A0A0276-14	Lead	ND	0.20	15	ppb
158-CH-4443-A-PP14-A	Hallway (124)	1/10/2020	1/14/2020	A0A0276-15	Lead	ND	0.20	15	ppb
158-CH-4449-A-PP14-A	Hallway (207)	1/10/2020	1/14/2020	A0A0276-16	Lead	0.36	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb