

Portland Public Schools
Pilot Program Lead and Copper Water Sampling Results
Initial Flush Sample Data
Gray Middle School - Test 17 Results

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
158-CH-4405-A-PP17-A	Hallway (100)	2/21/2020	2/27/2020	A0B0574-11	Lead	ND	0.2	15	ppb
158-CH-4414-A-PP17-A	Hallway (98)	2/21/2020	2/27/2020	A0B0574-12	Lead	ND	0.2	15	ppb
158-CH-4417-A-PP17-A	Hallway (111)	2/21/2020	2/27/2020	A0B0574-13	Lead	ND	0.2	15	ppb
158-CH-4424-A-PP17-A	Hallway (Boiler Rm)	2/21/2020	2/27/2020	A0B0574-14	Lead	ND	0.2	15	ppb
158-CH-4443-A-PP17-A	Hallway (124)	2/21/2020	2/27/2020	A0B0574-15	Lead	ND	0.2	15	ppb
158-CH-4449-A-PP17-A	Hallway (207)	2/21/2020	2/27/2020	A0B0574-16	Lead	0.598	0.2	15	ppb

*OSHA Lead Action Level = 15ppb