Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Abernathy Elementary School - Test 4

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
131-CH3518-A-004-A	Gym	5/1/2019	5/14/2019	A9E0111-01	Lead	0.973	0.20	15	ppb
131-CH3518-B-004-A	Gym	5/1/2019	5/14/2019	A9E0111-02	Lead	1.14	0.20	15	ppb
131-CH3512-N/A-004-A	Hallway (Main Office)	5/1/2019	5/14/2019	A9E0111-03	Lead	6.02	0.20	15	ppb
131-CH1051-A-004-A	Hallway (13)	5/1/2019	5/14/2019	A9E0111-04	Lead	2.73	0.20	15	ppb
131-CH1051-B-004-A	Hallway (13)	5/1/2019	5/14/2019	A9E0111-05	Lead	0.876	0.20	15	ppb
131-CH1039-N/A-004-A	Classroom 16	5/1/2019	5/14/2019	A9E0111-06	Lead	32.40	0.20	15	ppb
131-CH1042-A-004-A	Hallway (16&17)	5/1/2019	5/14/2019	A9E0111-07	Lead	5.09	0.20	15	ppb
131-CH1042-B-004-A	Hallway (16&17)	5/1/2019	5/14/2019	A9E0111-08	Lead	0.738	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek