

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Ainsworth Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
132-CH3545-N/A-003-A	Cafeteria	4/3/2019	4/16/2019	A9D0361-01	Lead	0.297	0.20	15	ppb
132-CH3565-N/A-003-A	Classroom 26	4/3/2019	4/16/2019	A9D0361-03	Lead	24.40	0.20	15	ppb
132-CH3553-N/A-003-A	Classroom 24	4/3/2019	4/16/2019	A9D0361-05	Lead	80.70	0.20	15	ppb
132-CH3562-N/A-003-A	Classroom 21	4/3/2019	4/16/2019	A9D0361-07	Lead	20.80	0.20	15	ppb
132-CH3550-N/A-003-A	Classroom 31	4/3/2019	4/16/2019	A9D0361-09	Lead	11.9	0.20	15	ppb
132-CH3547-N/A-003-A	Classroom 32	4/3/2019	4/16/2019	A9D0361-11	Lead	11.1	0.20	15	ppb
132-CH3544-N/A-003-A	Classroom 33	4/3/2019	4/16/2019	A9D0361-13	Lead	23.80	0.20	15	ppb
132-CH3541-N/A-003-A	Classroom 34	4/3/2019	4/16/2019	A9D0361-15	Lead	35.40	0.20	15	ppb
132-CH3569-N/A-003-A	Outside (Auditorium)	4/3/2019	4/16/2019	A9D0361-17	Lead	4.04	0.20	15	ppb
132-CH3572-N/A-003-A	Panda Room (Outside Under Stairs)	4/3/2019	4/16/2019	A9D0361-19	Lead	2.42	0.20	15	ppb
132-CH3575-N/A-003-A	Multi Purpose A5	4/3/2019	4/16/2019	A9D0361-21	Lead	34.20	0.20	15	ppb
132-CH3578-N/A-003-A	Classroom A4	4/3/2019	4/16/2019	A9D0361-23	Lead	4.17	0.20	15	ppb
132-CH3581-N/A-003-A	Classroom A3	4/3/2019	4/16/2019	A9D0361-25	Lead	7.55	0.20	15	ppb
132-CH3587-N/A-003-A	Annex Art Room	4/3/2019	4/16/2019	A9D0361-27	Lead	8.26	0.20	15	ppb
132-CH3567-N/A-003-A	Classroom A1	4/3/2019	4/16/2019	A9D0361-29	Lead	9.81	0.20	15	ppb
132-CH3590-N/A-003-A	Classroom A2	4/3/2019	4/16/2019	A9D0361-31	Lead	8.04	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.