

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Alameda Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
230-3911-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 115	7/26/2018	8/3/2018	A8G0703-01RE2	Copper	1.69	0.0200	1.3	ppm
230-3911-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 115	7/26/2018	8/3/2018	A8G0703-01RE1	Lead	4.79	2.00	15	ppb
230-3911-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 115	7/26/2018	8/2/2018	A8G0703-02	Copper	0.804	0.00200	1.3	ppm
230-3911-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 115	7/26/2018	8/2/2018	A8G0703-02	Lead	1.38	0.200	15	ppb
230-3914-N/A-001-A	Classroom Sink Bubbler - Classroom 110	7/26/2018	8/2/2018	A8G0703-03	Copper	0.914	0.00200	1.3	ppm
230-3914-N/A-001-A	Classroom Sink Bubbler - Classroom 110	7/26/2018	8/3/2018	A8G0703-03RE1	Lead	15.9	2.00	15	ppb
230-3914-N/A-001-B	Classroom Sink Bubbler - Classroom 110	7/26/2018	8/3/2018	A8G0703-04RE1	Copper	1.27	0.0200	1.3	ppm
230-3914-N/A-001-B	Classroom Sink Bubbler - Classroom 110	7/26/2018	8/2/2018	A8G0703-04	Lead	3.01	0.200	15	ppb
230-3908-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 111	7/26/2018	8/3/2018	A8G0703-05RE1	Copper	1.64	0.0200	1.3	ppm
230-3908-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 111	7/26/2018	8/2/2018	A8G0703-05	Lead	7.05	0.200	15	ppb
230-3908-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 111	7/26/2018	8/2/2018	A8G0703-06	Copper	0.914	0.00200	1.3	ppm
230-3908-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 111	7/26/2018	8/2/2018	A8G0703-06	Lead	1.28	0.200	15	ppb
230-3877-N/A-001-A	Classroom Sink Bubbler - Classroom 102	7/26/2018	8/2/2018	A8G0703-07	Copper	0.00295	0.00200	1.3	ppm
230-3877-N/A-001-A	Classroom Sink Bubbler - Classroom 102	7/26/2018	8/2/2018	A8G0703-07	Lead	3.48	0.200	15	ppb
230-3877-N/A-001-B	Classroom Sink Bubbler - Classroom 102	7/26/2018	8/2/2018	A8G0703-08	Copper	ND	0.00200	1.3	ppm
230-3877-N/A-001-B	Classroom Sink Bubbler - Classroom 102	7/26/2018	8/2/2018	A8G0703-08	Lead	0.649	0.200	15	ppb
230-3886-N/A-001-A	Classroom Sink Bubbler - Classroom 101	7/26/2018	8/2/2018	A8G0703-09	Copper	0.0145	0.00200	1.3	ppm
230-3886-N/A-001-A	Classroom Sink Bubbler - Classroom 101	7/26/2018	8/2/2018	A8G0703-09	Lead	3.64	0.200	15	ppb
230-3886-N/A-001-B	Classroom Sink Bubbler - Classroom 101	7/26/2018	8/2/2018	A8G0703-10	Copper	0.00362	0.00200	1.3	ppm
230-3886-N/A-001-B	Classroom Sink Bubbler - Classroom 101	7/26/2018	8/2/2018	A8G0703-10	Lead	0.659	0.200	15	ppb
230-3880-N/A-001-A	Classroom Sink Bubbler - Classroom 100	7/26/2018	8/2/2018	A8G0703-11	Copper	0.0240	0.00200	1.3	ppm
230-3880-N/A-001-A	Classroom Sink Bubbler - Classroom 100	7/26/2018	8/2/2018	A8G0703-11	Lead	5.04	0.200	15	ppb
230-3880-N/A-001-B	Classroom Sink Bubbler - Classroom 100	7/26/2018	8/2/2018	A8G0703-12	Copper	0.00331	0.00200	1.3	ppm

230-3880-N/A-001-B	Classroom Sink Bubbler - Classroom 100	7/26/2018	8/2/2018	A8G0703-12	Lead	1.33	0.200	15	ppb
230-3899-N/A-001-A	Classroom Sink Bubbler - Classroom 203	7/26/2018	8/2/2018	A8G0703-13	Copper	0.0164	0.00200	1.3	ppm
230-3899-N/A-001-A	Classroom Sink Bubbler - Classroom 203	7/26/2018	8/2/2018	A8G0703-13	Lead	6.75	0.200	15	ppb
230-3899-N/A-001-B	Classroom Sink Bubbler - Classroom 203	7/26/2018	8/2/2018	A8G0703-14	Copper	0.00432	0.00200	1.3	ppm
230-3899-N/A-001-B	Classroom Sink Bubbler - Classroom 203	7/26/2018	8/2/2018	A8G0703-14	Lead	1.35	0.200	15	ppb
230-3892-N/A-001-A	Sink (Food Prep) - Staff 130	7/26/2018	8/3/2018	A8G0703-15RE1	Copper	1.24	0.0200	1.3	ppm
230-3892-N/A-001-A	Sink (Food Prep) - Staff 130	7/26/2018	8/2/2018	A8G0703-15	Lead	ND	2.00	15	ppb
230-3892-N/A-001-B	Sink (Food Prep) - Staff 130	7/26/2018	8/2/2018	A8G0703-16	Copper	0.535	0.00200	1.3	ppm
230-3892-N/A-001-B	Sink (Food Prep) - Staff 130	7/26/2018	8/2/2018	A8G0703-16	Lead	0.570	0.200	15	ppb
230-3874-N/A-001-A	Classroom Sink Bubbler - Portable 1	7/26/2018	8/2/2018	A8G0703-17	Copper	0.617	0.00200	1.3	ppm
230-3874-N/A-001-A	Classroom Sink Bubbler - Portable 1	7/26/2018	8/2/2018	A8G0703-17	Lead	1.98	0.200	15	ppb
230-3874-N/A-001-B	Classroom Sink Bubbler - Portable 1	7/26/2018	8/2/2018	A8G0703-18	Copper	0.913	0.00200	1.3	ppm
230-3874-N/A-001-B	Classroom Sink Bubbler - Portable 1	7/26/2018	8/2/2018	A8G0703-18	Lead	5.31	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.