

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Alameda Elementary School- Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
230-CH3905-N/A-004-A	Classroom 107	3/27/2019	4/9/2019	A9C1073-01	Lead	7.49	0.20	15	ppb
230-CH3883-N/A-004-A	Classroom 103	3/27/2019	4/9/2019	A9C1073-03	Lead	1.87	0.20	15	ppb
230-CH3890-N/A-004-A	Classroom 200	3/27/2019	4/9/2019	A9C1073-05	Lead	6.82	0.20	15	ppb
230-CH3893-N/A-004-A	Classroom 201	3/27/2019	4/9/2019	A9C1073-07	Lead	3.32	0.20	15	ppb
230-CH3902-N/A-004-A	Classroom 202	3/27/2019	4/9/2019	A9C1073-09	Lead	8.53	0.20	15	ppb
230-CH3898-N/A-004-A	Classroom 139	3/27/2019	4/9/2019	A9C1073-11	Lead	29.60	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.