

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Applegate Head Start

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
134-3063-N/A-001-A	Drinking Fountain (Metal) - Classroom 3	7/24/2018	8/2/2018	A8G0617-01RE3	Copper	1.35	0.0200	1.3	ppm
134-3063-N/A-001-A	Drinking Fountain (Metal) - Classroom 3	7/24/2018	8/2/2018	A8G0617-01RE2	Lead	1.17	0.200	15	ppb
134-3063-N/A-001-B	Drinking Fountain (Metal) - Classroom 3	7/24/2018	8/2/2018	A8G0617-02RE3	Copper	1.25	0.0200	1.3	ppm
134-3063-N/A-001-B	Drinking Fountain (Metal) - Classroom 3	7/24/2018	8/2/2018	A8G0617-02RE2	Lead	0.487	0.200	15	ppb
134-3060-N/A-001-A	Classroom Sink Bubbler - Classroom 4	7/24/2018	8/2/2018	A8G0617-03RE1	Copper	0.754	0.00200	1.3	ppm
134-3060-N/A-001-A	Classroom Sink Bubbler - Classroom 4	7/24/2018	8/2/2018	A8G0617-03RE1	Lead	3.84	0.200	15	ppb
134-3060-N/A-001-B	Classroom Sink Bubbler - Classroom 4	7/24/2018	8/2/2018	A8G0617-04RE1	Copper	0.700	0.00200	1.3	ppm
134-3060-N/A-001-B	Classroom Sink Bubbler - Classroom 4	7/24/2018	8/2/2018	A8G0617-04RE1	Lead	0.703	0.200	15	ppb
134-3077-N/A-001-A	Classroom Sink Bubbler - Classroom 7	7/24/2018	7/27/2018	A8G0617-05RE1	Copper	0.814	0.0100	1.3	ppm
134-3077-N/A-001-A	Classroom Sink Bubbler - Classroom 7	7/24/2018	7/26/2018	A8G0617-05	Lead	3.43	0.200	15	ppb
134-3077-N/A-001-B	Classroom Sink Bubbler - Classroom 7	7/24/2018	7/27/2018	A8G0617-06RE1	Copper	0.862	0.0100	1.3	ppm
134-3077-N/A-001-B	Classroom Sink Bubbler - Classroom 7	7/24/2018	7/26/2018	A8G0617-06	Lead	1.51	0.200	15	ppb
134-3068-N/A-001-A	Classroom Sink Bubbler - Classroom 9	7/24/2018	7/27/2018	A8G0617-07RE1	Copper	0.980	0.0100	1.3	ppm
134-3068-N/A-001-A	Classroom Sink Bubbler - Classroom 9	7/24/2018	7/26/2018	A8G0617-07	Lead	7.58	0.200	15	ppb
134-3068-N/A-001-B	Classroom Sink Bubbler - Classroom 9	7/24/2018	7/27/2018	A8G0617-08RE1	Copper	1.00	0.0100	1.3	ppm
134-3068-N/A-001-B	Classroom Sink Bubbler - Classroom 9	7/24/2018	7/26/2018	A8G0617-08	Lead	1.59	0.200	15	ppb
134-3053-N/A-001-A	Classroom Sink Bubbler - Classroom 12	7/24/2018	7/27/2018	A8G0617-09RE1	Copper	0.853	0.0100	1.3	ppm
134-3053-N/A-001-A	Classroom Sink Bubbler - Classroom 12	7/24/2018	7/26/2018	A8G0617-09	Lead	20.8	0.200	15	ppb
134-3053-N/A-001-B	Classroom Sink Bubbler - Classroom 12	7/24/2018	7/27/2018	A8G0617-10RE1	Copper	0.947	0.0100	1.3	ppm
134-3053-N/A-001-B	Classroom Sink Bubbler - Classroom 12	7/24/2018	7/26/2018	A8G0617-10	Lead	8.84	0.200	15	ppb
134-3054-N/A-001-A	Classroom Sink Bubbler - Classroom 6	7/24/2018	7/27/2018	A8G0617-11RE1	Copper	0.891	0.0100	1.3	ppm
134-3054-N/A-001-A	Classroom Sink Bubbler - Classroom 6	7/24/2018	7/26/2018	A8G0617-11	Lead	3.95	0.200	15	ppb
134-3054-N/A-001-B	Classroom Sink Bubbler - Classroom 6	7/24/2018	7/27/2018	A8G0617-12RE1	Copper	0.905	0.0100	1.3	ppm

134-3054-N/A-001-B	Classroom Sink Bubbler - Classroom 6	7/24/2018	7/26/2018	A8G0617-12	Lead	0.727	0.200	15	ppb
134-3069-N/A-001-A	Classroom Sink Bubbler - Portable Classroom	7/24/2018	7/27/2018	A8G0617-13RE1	Copper	0.0246	0.00200	1.3	ppm
134-3069-N/A-001-A	Classroom Sink Bubbler - Portable Classroom	7/24/2018	7/26/2018	A8G0617-13	Lead	24.8	0.200	15	ppb
134-3069-N/A-001-B	Classroom Sink Bubbler - Portable Classroom	7/24/2018	7/26/2018	A8G0617-14	Copper	0.00612	0.00200	1.3	ppm
134-3069-N/A-001-B	Classroom Sink Bubbler - Portable Classroom	7/24/2018	7/26/2018	A8G0617-14	Lead	7.57	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.