

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Applegate - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
134-CH3066-N/A-003-A	Hallway (2)	3/26/2019	4/9/2019	A9C1077-01	Lead	2.84	0.20	15	ppb
134-CH3057-N/A-003-A	Classroom 5	3/27/2019	4/9/2019	A9C1077-03	Lead	1.45	0.20	15	ppb
134-CH3071-N/A-003-A	Classroom 8	3/28/2019	4/10/2019	A9C1077-05	Lead	2.74	0.20	15	ppb
134-CH3065-N/A-003-A	Kitchen	3/29/2019	4/10/2019	A9C1077-07	Lead	3.79	0.20	15	ppb
134-CH3062-N/A-003-A	Classroom 10	3/30/2019	4/10/2019	A9C1077-09	Lead	2.62	0.20	15	ppb
134-CH3059-N/A-003-A	Classroom 11	3/31/2019	4/10/2019	A9C1077-11	Lead	2.32	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15 ppb