

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Arleta School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
232-5219-A-001A 1st Floor near Rm 8B	08/06/18 10:09 AM	08/08/18 2:49 PM	18017771	Copper	< 0.1	1.3	ppm
232-5219-A-001A 1st Floor near Rm 8B	08/06/18 10:09 AM	08/08/18 2:49 PM	18017771	Lead	11	15	ppb
232-5219-A-001B 1st Floor near Rm 8B	08/06/18 10:09 AM	08/08/18 2:51 PM	18017776	Copper	< 0.1	1.3	ppm
232-5219-A-001B 1st Floor near Rm 8B	08/06/18 10:09 AM	08/08/18 2:51 PM	18017776	Lead	5	15	ppb
232-5225-A-001A 7H Hallway	08/06/18 10:15 AM	08/08/18 2:52 PM	18017775	Copper	< 0.1	1.3	ppm
232-5225-A-001A 7H Hallway	08/06/18 10:15 AM	08/08/18 2:52 PM	18017775	Lead	10	15	ppb
232-5225-A-001B 7H Hallway	08/06/18 10:15 AM	08/08/18 2:54 PM	18017774	Copper	< 0.1	1.3	ppm
232-5225-A-001B 7H Hallway	08/06/18 10:15 AM	08/08/18 2:54 PM	18017774	Lead	< 1	15	ppb
232-5225-B-001A 7H Hallway	08/06/18 10:15 AM	08/08/18 2:56 PM	18017773	Copper	< 0.1	1.3	ppm
232-5225-B-001A 7H Hallway	08/06/18 10:15 AM	08/08/18 2:56 PM	18017773	Lead	2	15	ppb
232-5225-B-001B 7H Hallway	08/06/18 10:15 AM	08/08/18 3:09 PM	18017772	Copper	< 0.1	1.3	ppm
232-5225-B-001B 7H Hallway	08/06/18 10:15 AM	08/08/18 3:09 PM	18017772	Lead	< 1	15	ppb
232-5228-A-001A Near Gym/Auditorium	08/06/18 10:22 AM	08/08/18 3:10 PM	18017769	Copper	< 0.1	1.3	ppm
232-5228-A-001A Near Gym/Auditorium	08/06/18 10:22 AM	08/08/18 3:10 PM	18017769	Lead	19	15	ppb
232-5228-A-001B Near Gym/Auditorium	08/06/18 10:22 AM	08/08/18 3:12 PM	18017768	Copper	< 0.1	1.3	ppm
232-5228-A-001B Near Gym/Auditorium	08/06/18 10:22 AM	08/08/18 3:12 PM	18017768	Lead	7	15	ppb
232-5234-A-001A Near Rm 3	08/06/18 10:27 AM	08/08/18 3:14 PM	18017778	Copper	< 0.1	1.3	ppm
232-5234-A-001A Near Rm 3	08/06/18 10:27 AM	08/08/18 3:14 PM	18017778	Lead	31	15	ppb
232-5234-A-001B Near Rm 3	08/06/18 10:27 AM	08/08/18 3:16 PM	18017781	Copper	< 0.1	1.3	ppm
232-5234-A-001B Near Rm 3	08/06/18 10:27 AM	08/08/18 3:16 PM	18017781	Lead	< 1	15	ppb
232-5234-B-001A Near Rm 3	08/06/18 10:27 AM	08/08/18 3:18 PM	18017767	Copper	< 0.1	1.3	ppm
232-5234-B-001A Near Rm 3	08/06/18 10:27 AM	08/08/18 3:18 PM	18017767	Lead	9	15	ppb
232-5234-B-001B Near Rm 3	08/06/18 10:27 AM	08/08/18 3:19 PM	18017770	Copper	< 0.1	1.3	ppm
232-5234-B-001B Near Rm 3	08/06/18 10:27 AM	08/08/18 3:19 PM	18017770	Lead	< 1	15	ppb
232-5223-A-001A 2nd Floor near Rm 20	08/06/18 10:39 AM	08/08/18 3:21 PM	18017779	Copper	< 0.1	1.3	ppm
232-5223-A-001A 2nd Floor near Rm 20	08/06/18 10:39 AM	08/08/18 3:21 PM	18017779	Lead	16	15	ppb
232-5223-A-001B 2nd Floor near Rm 20	08/06/18 10:39 AM	08/08/18 3:23 PM	18017766	Copper	< 0.1	1.3	ppm
232-5223-A-001B 2nd Floor near Rm 20	08/06/18 10:39 AM	08/08/18 3:23 PM	18017766	Lead	21	15	ppb
232-5220-A-001A 2nd Floor Hallway	08/06/18 10:48 AM	08/08/18 3:34 PM	18017777	Copper	< 0.1	1.3	ppm
232-5220-A-001A 2nd Floor Hallway	08/06/18 10:48 AM	08/08/18 3:34 PM	18017777	Lead	34	15	ppb
232-5220-A-001B 2nd Floor Hallway	08/06/18 10:48 AM	08/08/18 3:36 PM	18017780	Copper	< 0.1	1.3	ppm
232-5220-A-001B 2nd Floor Hallway	08/06/18 10:48 AM	08/08/18 3:36 PM	18017780	Lead	31	15	ppb
232-5220-B-001A 2nd Floor Hallway	08/06/18 10:50 AM	08/08/18 3:38 PM	18017782	Copper	< 0.1	1.3	ppm
232-5220-B-001A 2nd Floor Hallway	08/06/18 10:50 AM	08/08/18 3:38 PM	18017782	Lead	36	15	ppb
232-5220-B-001B 2nd Floor Hallway	08/06/18 10:50 AM	08/08/18 3:39 PM	18017783	Copper	< 0.1	1.3	ppm
232-5220-B-001B 2nd Floor Hallway	08/06/18 10:50 AM	08/08/18 3:39 PM	18017783	Lead	17	15	ppb
232-5214-A-001A 2nd Floor near Rm 15	08/06/18 11:00 AM	08/08/18 3:41 PM	18017784	Copper	< 0.1	1.3	ppm
232-5214-A-001A 2nd Floor near Rm 15	08/06/18 11:00 AM	08/08/18 3:41 PM	18017784	Lead	17	15	ppb
232-5214-A-001B 2nd Floor near Rm 15	08/06/18 11:00 AM	08/08/18 3:43 PM	18017785	Copper	< 0.1	1.3	ppm
232-5214-A-001B 2nd Floor near Rm 15	08/06/18 11:00 AM	08/08/18 3:43 PM	18017785	Lead	5	15	ppb
232-5214-B-001A 2nd Floor near Rm 15	08/06/18 11:00 AM	08/08/18 3:45 PM	18017786	Copper	< 0.1	1.3	ppm
232-5214-B-001A 2nd Floor near Rm 15	08/06/18 11:00 AM	08/08/18 3:45 PM	18017786	Lead	8	15	ppb
232-5214-B-001B 2nd Floor near Rm 15	08/06/18 11:00 AM	08/08/18 3:47 PM	18017787	Copper	< 0.1	1.3	ppm
232-5214-B-001B 2nd Floor near Rm 15	08/06/18 11:00 AM	08/08/18 3:47 PM	18017787	Lead	19	15	ppb
232-5217-A-001A 2nd Floor near Rm 13	08/06/18 11:08 AM	08/08/18 3:48 PM	18017788	Copper	< 0.1	1.3	ppm
232-5217-A-001A 2nd Floor near Rm 13	08/06/18 11:08 AM	08/08/18 3:48 PM	18017788	Lead	19	15	ppb
232-5217-A-001B 2nd Floor near Rm 13	08/06/18 11:08 AM	08/08/18 3:50 PM	18017789	Copper	< 0.1	1.3	ppm
232-5217-A-001B 2nd Floor near Rm 13	08/06/18 11:08 AM	08/08/18 3:50 PM	18017789	Lead	22	15	ppb
232-5238-A-001A Outside Cafeteria	08/06/18 11:17 AM	08/08/18 4:03 PM	18017790	Copper	< 0.1	1.3	ppm
232-5238-A-001A Outside Cafeteria	08/06/18 11:17 AM	08/08/18 4:03 PM	18017790	Lead	9	15	ppb
232-5238-A-001B Outside Cafeteria	08/06/18 11:17 AM	08/08/18 4:05 PM	18017791	Copper	< 0.1	1.3	ppm
232-5238-A-001B Outside Cafeteria	08/06/18 11:17 AM	08/08/18 4:05 PM	18017791	Lead	8	15	ppb
232-5226-A-001A Kitchen	08/06/18 11:22 AM	08/08/18 4:07 PM	18017792	Copper	< 0.1	1.3	ppm
232-5226-A-001A Kitchen	08/06/18 11:22 AM	08/08/18 4:07 PM	18017792	Lead	6	15	ppb
232-5226-A-001B Kitchen	08/06/18 11:22 AM	08/08/18 4:08 PM	18017793	Copper	< 0.1	1.3	ppm

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Arleta School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
232-5226-A-001B Kitchen	08/06/18 11:22 AM	08/08/18 4:08 PM	18017793	Lead	5.7	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.