

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Arleta K-8 School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
232-CH5215-N/A-003-A	Classroom 33	3/29/2019	4/9/2019	A9C1058-01	Lead	27.50	0.20	15	ppb
232-CH5228-N/A-003-A	Hallway (Gym)	3/29/2019	4/9/2019	A9C1058-03	Lead	13.2	0.20	15	ppb
232-CH5237-N/A-003-A	Hallway (2)	3/29/2019	4/9/2019	A9C1058-05	Lead	25.20	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.