Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
2nd Site Visit - Atkinson Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
234-1147-NA-001-A	Faucet - Classroom 165	9/11/2018	9/13/2018	A8I0237-01	Copper	0.120	0.00200	1.3	ppm
234-1147-NA-001-A	Faucet - Classroom 165	9/11/2018	9/13/2018	A8I0237-01	Lead	2.54	0.200	15	ppb
234-1147-NA-001-B	Faucet - Classroom 165	9/11/2018	9/13/2018	A8I0237-02	Copper	0.0182	0.00200	1.3	ppm
234-1147-NA-001-B	Faucet - Classroom 165	9/11/2018	9/13/2018	A8I0237-02	Lead	0.379	0.200	15	ppb
234-1150-NA-001-A	Drinking Fountain (Porcelain) - Classroom 124/164	9/11/2018	9/13/2018	A8I0237-03	Copper	0.0836	0.00200	1.3	ppm
234-1150-NA-001-A	Drinking Fountain (Porcelain) - Classroom 124/164	9/11/2018	9/13/2018	A8I0237-03	Lead	7.28	0.200	15	ppb
234-1150-NA-001-B	Drinking Fountain (Porcelain) - Classroom 124/164	9/11/2018	9/13/2018	A8I0237-04	Copper	0.0552	0.00200	1.3	ppm
234-1150-NA-001-B	Drinking Fountain (Porcelain) - Classroom 124/164	9/11/2018	9/13/2018	A8I0237-04	Lead	4.69	0.200	15	ppb
234-1149-NA-001-A	Sink Bubbler - Classroom 125	9/11/2018	9/13/2018	A8I0237-05	Copper	0.612	0.00200	1.3	ppm
234-1149-NA-001-A	Sink Bubbler - Classroom 125	9/11/2018	9/13/2018	A8I0237-05	Lead	4.34	0.200	15	ppb
234-1149-NA-001-B	Sink Bubbler - Classroom 125	9/11/2018	9/13/2018	A8I0237-06	Copper	0.684	0.00200	1.3	ppm
234-1149-NA-001-B	Sink Bubbler - Classroom 125	9/11/2018	9/13/2018	A8I0237-06	Lead	1.05	0.200	15	ppb
234-1153-NA-001-A	Drinking Fountain (Porcelain) - Classroom 119	9/11/2018	9/13/2018	A8I0237-07	Copper	0.0815	0.00200	1.3	ppm
234-1153-NA-001-A	Drinking Fountain (Porcelain) - Classroom 119	9/11/2018	9/13/2018	A8I0237-07	Lead	7.50	0.200	15	ppb
234-1153-NA-001-B	Drinking Fountain (Porcelain) - Classroom 119	9/11/2018	9/13/2018	A8I0237-08	Copper	0.143	0.00200	1.3	ppm
234-1153-NA-001-B	Drinking Fountain (Porcelain) - Classroom 119	9/11/2018	9/13/2018	A8I0237-08	Lead	0.688	0.200	15	ppb
234-1156-NA-001-A	Drinking Fountain (Porcelain) - Classroom 115	9/11/2018	9/13/2018	A8I0237-09	Copper	0.155	0.00200	1.3	ppm
234-1156-NA-001-A	Drinking Fountain (Porcelain) - Classroom 115	9/11/2018	9/13/2018	A8I0237-09	Lead	5.35	0.200	15	ppb
234-1156-NA-001-B	Drinking Fountain (Porcelain) - Classroom 115	9/11/2018	9/13/2018	A8I0237-10	Copper	0.168	0.00200	1.3	ppm
234-1156-NA-001-B	Drinking Fountain (Porcelain) - Classroom 115	9/11/2018	9/13/2018	A8I0237-10	Lead	2.10	0.200	15	ppb
234-1141-NA-001-A	Sink Bubbler - Gym	9/11/2018	9/13/2018	A8I0237-11	Copper	0.241	0.00200	1.3	ppm
234-1141-NA-001-A	Sink Bubbler - Gym	9/11/2018	9/13/2018	A8I0237-11	Lead	10.7	0.200	15	ppb
234-1141-NA-001-B	Sink Bubbler - Gym	9/11/2018	9/13/2018	A8I0237-12	Copper	0.0389	0.00200	1.3	ppm
234-1141-NA-001-B	Sink Bubbler - Gym	9/11/2018	9/13/2018	A8I0237-12	Lead	2.05	0.200	15	ppb

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Analyzed by: Apex Laboratories
Reviewed by: G2 Consultants, Inc.