

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Beach**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
140-CH3086-N/A-001-A	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-41RE1	Copper	1.10	0.00500	1.3	ppm
140-CH3086-N/A-001-A	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-41	Lead	2.51	0.200	15	ppb
140-CH3086-N/A-001-B	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-42RE1	Copper	0.888	0.00500	1.3	ppm
140-CH3086-N/A-001-B	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-42	Lead	0.373	0.200	15	ppb
140-CH3089-A-001-A	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-37	Copper	0.389	0.00100	1.3	ppm
140-CH3089-A-001-A	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-37	Lead	2.79	0.200	15	ppb
140-CH3089-A-001-B	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-38	Copper	0.109	0.00100	1.3	ppm
140-CH3089-A-001-B	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-38	Lead	ND	0.200	15	ppb
140-CH3089-B-001-A	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-39	Copper	0.113	0.00100	1.3	ppm
140-CH3089-B-001-A	Cafeteria Bubbler	3/3/2018	3/12/2018	A8C0124-39	Lead	0.550	0.200	15	ppb
140-CH3089-B-001-B	Cafeteria Bubbler	3/3/2018	3/13/2018	A8C0124-40	Copper	0.0949	0.00100	1.3	ppm
140-CH3089-B-001-B	Bubbler	3/3/2018	3/13/2018	A8C0124-40	Lead	ND	0.200	15	ppb
140-CH3101-N/A-001-A	Hall Bubbler	3/3/2018	3/12/2018	A8C0124-31	Copper	0.203	0.00100	1.3	ppm
140-CH3101-N/A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-31	Lead	0.397	0.200	15	ppb
140-CH3101-N/A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-32	Copper	0.304	0.00100	1.3	ppm
140-CH3101-N/A-001-B	Hall Bubbler	3/3/2018	3/12/2018	A8C0124-32	Lead	ND	0.200	15	ppb
140-CH3108-A-001-A	Hall Bubbler	3/3/2018	3/12/2018	A8C0124-21RE1	Copper	0.475	0.00500	1.3	ppm

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

140-CH3108-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-21	Lead	4.01	0.200	15	ppb
140-CH3108-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-22RE1	Copper	0.575	0.00500	1.3	ppm
140-CH3108-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-22	Lead	0.271	0.200	15	ppb
140-CH3108-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-23	Copper	0.337	0.00100	1.3	ppm
140-CH3108-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-23	Lead	0.662	0.200	15	ppb
140-CH3108-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-24	Copper	0.238	0.00100	1.3	ppm
140-CH3108-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-24	Lead	ND	0.200	15	ppb
140-CH3110-N/A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-03	Copper	0.280	0.00100	1.3	ppm
140-CH3110-N/A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-03	Lead	0.751	0.200	15	ppb
140-CH3110-N/A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-04	Copper	0.224	0.00100	1.3	ppm
140-CH3110-N/A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-04	Lead	ND	0.200	15	ppb
140-CH3111-N/A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-25	Copper	0.349	0.00100	1.3	ppm
140-CH3111-N/A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-25	Lead	0.587	0.200	15	ppb
140-CH3111-N/A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-26	Copper	0.137	0.00100	1.3	ppm
140-CH3111-N/A-001-B	Hall Bubbler Hall Water	3/3/2018	3/13/2018	A8C0124-26	Lead	ND	0.200	15	ppb
140-CH3113-N/A-001-A	Bottle Filler Hall Water	3/3/2018	3/13/2018	A8C0124-01	Copper	0.331	0.00100	1.3	ppm
140-CH3113-N/A-001-A	Bottle Filler Hall Water	3/3/2018	3/13/2018	A8C0124-01	Lead	1.06	0.200	15	ppb
140-CH3113-N/A-001-B	Bottle Filler Hall Water	3/3/2018	3/13/2018	A8C0124-02	Copper	0.346	0.00100	1.3	ppm
140-CH3113-N/A-001-B	Bottle Filler	3/3/2018	3/13/2018	A8C0124-02	Lead	ND	0.200	15	ppb
140-CH3114-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-27RE1	Copper	1.02	0.00500	1.3	ppm
140-CH3114-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-27	Lead	8.38	0.200	15	ppb
140-CH3114-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-28RE1	Copper	1.29	0.00500	1.3	ppm

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

140-CH3114-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-28	Lead	0.415	0.200	15	ppb
140-CH3114-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-29RE1	Copper	1.01	0.00500	1.3	ppm
140-CH3114-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-29	Lead	0.847	0.200	15	ppb
140-CH3114-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-30RE1	Copper	0.688	0.00500	1.3	ppm
140-CH3114-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-30	Lead	0.485	0.200	15	ppb
140-CH3116-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-05	Copper	1.47	0.00500	1.3	ppm
140-CH3116-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-05RE1	Lead	5.51	0.200	15	ppb
140-CH3116-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-06	Copper	0.756	0.00500	1.3	ppm
140-CH3116-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-06RE1	Lead	0.303	0.200	15	ppb
140-CH3116-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-07	Copper	0.644	0.00500	1.3	ppm
140-CH3116-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-07RE1	Lead	1.13	0.200	15	ppb
140-CH3116-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-08	Copper	0.453	0.00100	1.3	ppm
140-CH3116-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-08	Lead	0.490	0.200	15	ppb
140-CH3119-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-09	Copper	0.456	0.00100	1.3	ppm
140-CH3119-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-09	Lead	4.75	0.200	15	ppb
140-CH3119-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-10RE1	Copper	0.636	0.00500	1.3	ppm
140-CH3119-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-10	Lead	0.353	0.200	15	ppb
140-CH3119-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-11RE1	Copper	0.582	0.00500	1.3	ppm
140-CH3119-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-11	Lead	0.865	0.200	15	ppb
140-CH3119-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-12	Copper	0.432	0.00100	1.3	ppm
140-CH3119-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-12	Lead	0.305	0.200	15	ppb
140-CH3122-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-13RE1	Copper	0.551	0.00500	1.3	ppm

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

140-CH3122-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-13	Lead	0.943	0.200	15	ppb
140-CH3122-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-14	Copper	0.465	0.00100	1.3	ppm
140-CH3122-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-14	Lead	ND	0.200	15	ppb
140-CH3122-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-15	Copper	0.253	0.00100	1.3	ppm
140-CH3122-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-15	Lead	0.465	0.200	15	ppb
140-CH3122-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-16	Copper	0.190	0.00100	1.3	ppm
140-CH3122-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-16	Lead	ND	0.200	15	ppb
140-CH3128-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-17	Copper	0.436	0.00100	1.3	ppm
140-CH3128-A-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-17	Lead	0.693	0.200	15	ppb
140-CH3128-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-18	Copper	0.498	0.00100	1.3	ppm
140-CH3128-A-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-18	Lead	ND	0.200	15	ppb
140-CH3128-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-19	Copper	0.319	0.00100	1.3	ppm
140-CH3128-B-001-A	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-19	Lead	0.310	0.200	15	ppb
140-CH3128-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-20	Copper	0.215	0.00100	1.3	ppm
140-CH3128-B-001-B	Hall Bubbler	3/3/2018	3/13/2018	A8C0124-20	Lead	ND	0.200	15	ppb
140-CH3132-N/A-001-A	Annex Bubbler	3/3/2018	3/13/2018	A8C0124-43	Copper	0.341	0.00100	1.3	ppm
140-CH3132-N/A-001-A	Annex Bubbler	3/3/2018	3/13/2018	A8C0124-43	Lead	0.424	0.200	15	ppb
140-CH3132-N/A-001-B	Annex Bubbler	3/3/2018	3/13/2018	A8C0124-44	Copper	0.327	0.00100	1.3	ppm
140-CH3132-N/A-001-B	Annex Bubbler	3/3/2018	3/13/2018	A8C0124-44	Lead	ND	0.200	15	ppb
140-CH3092-A-001-A	Kitchen Sprayer	3/3/2018	3/13/2018	A8C0124-33	Copper	0.149	0.00100	1.3	ppm
140-CH3092-A-001-A	Kitchen Sprayer	3/3/2018	3/13/2018	A8C0124-33	Lead	1.74	0.200	15	ppb
140-CH3092-A-001-B	Kitchen Sprayer	3/3/2018	3/13/2018	A8C0124-34	Copper	0.180	0.00100	1.3	ppm

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

140-CH3092-A-001-B	Kitchen Sprayer	3/3/2018	3/13/2018	A8C0124-34	Lead	0.563	0.200	15	ppb
140-CH3092-B-001-A	Kitchen Faucet	3/3/2018	3/13/2018	A8C0124-35RE1	Copper	0.719	0.00500	1.3	ppm
140-CH3092-B-001-A	Kitchen Faucet	3/3/2018	3/13/2018	A8C0124-35	Lead	1.00	0.200	15	ppb
140-CH3092-B-001-B	Kitchen Faucet	3/3/2018	3/13/2018	A8C0124-36	Copper	0.150	0.00100	1.3	ppm
140-CH3092-B-001-B	Kitchen Faucet	3/3/2018	3/13/2018	A8C0124-36	Lead	0.201	0.200	15	ppb

Results highlighted yellow indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.