

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Beach School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
140-CH3133-N/A-004-A	Classroom A4	4/16/2019	4/25/2019	A9D0760-01	Lead	7.41	0.20	15	ppb
140-CH3121-N/A-004-A	Classroom A8	4/16/2019	4/25/2019	A9D0760-02	Lead	2.76	0.20	15	ppb
140-CH3129-N/A-004-A	Classroom A13	4/16/2019	4/25/2019	A9D0760-03	Lead	4.34	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb