

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Beaumont Middle School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
235-CH####-N/A-003-A	Portable Hallway (1/3)	3/27/2019	4/10/2019	A9C1083-01	Lead	0.93	0.20	15	ppb
235-CH1650-A-003-A	Hallway (1st Floor by Gym)	3/27/2019	4/10/2019	A9C1083-03	Lead	5.45	0.20	15	ppb
235-CH1650-B-003-A	Hallway (1st Floor by Gym)	3/27/2019	4/10/2019	A9C1083-05	Lead	9.73	0.20	15	ppb
235-CH1656-N/A-003-A	Gym 111/109	3/27/2019	4/10/2019	A9C1083-07	Lead	111.00	0.20	15	ppb
235-CH1666-N/A-003-A	Hallway (1st Floor by Cafeteria)	3/27/2019	4/10/2019	A9C1083-09	Lead	1.27	0.20	15	ppb
235-CH1665-N/A-003-A	Hallway Basement 14A	3/27/2019	4/10/2019	A9C1083-11	Lead	1.8	0.20	15	ppb
235-CH1649-A-003-A	Hallway (218)	3/27/2019	4/10/2019	A9C1083-13	Lead	66.00	0.20	15	ppb
235-CH1649-B-003-A	Hallway (218)	3/27/2019	4/10/2019	A9C1083-15	Lead	15.90	0.20	15	ppb
235-CH####-A-003-A	Hallway (202)	3/27/2019	4/10/2019	A9C1083-17	Lead	3.08	0.20	15	ppb
235-CH####-B-003-A	Hallway (202)	3/27/2019	4/10/2019	A9C1083-19	Lead	6.31	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.