

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Beverly Cleary - Fernwood Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
249-1720-N/A-001-A	Water Cooler - Main office/nurse	7/25/2018	8/1/2018	A8G0665-01RE1	Copper	1.06	0.0200	1.3	ppm
249-1720-N/A-001-A	Water Cooler - Main office/nurse	7/25/2018	8/1/2018	A8G0665-01RE2	Lead	22.2	0.200	15	ppb
249-1720-N/A-001-B	Water Cooler - Main office/nurse	7/25/2018	7/31/2018	A8G0665-02	Copper	0.432	0.00200	1.3	ppm
249-1720-N/A-001-B	Water Cooler - Main office/nurse	7/25/2018	8/1/2018	A8G0665-02RE1	Lead	3.05	0.200	15	ppb
249-1729-N/A-001-A	Classroom Sink Bubbler - Classroom 139	7/25/2018	7/31/2018	A8G0665-03	Copper	0.976	0.00200	1.3	ppm
249-1729-N/A-001-A	Classroom Sink Bubbler - Classroom 139	7/25/2018	8/1/2018	A8G0665-03RE2	Lead	5.50	0.200	15	ppb
249-1729-N/A-001-B	Classroom Sink Bubbler - Classroom 139	7/25/2018	8/1/2018	A8G0665-04RE1	Copper	1.16	0.0200	1.3	ppm
249-1729-N/A-001-B	Classroom Sink Bubbler - Classroom 139	7/25/2018	8/1/2018	A8G0665-04RE2	Lead	1.48	0.200	15	ppb
249-1726-N/A-001-A	Classroom Sink Bubbler - Classroom 139	7/25/2018	7/31/2018	A8G0665-05	Copper	0.979	0.00200	1.3	ppm
249-1726-N/A-001-A	Classroom Sink Bubbler - Classroom 139	7/25/2018	8/1/2018	A8G0665-05RE2	Lead	2.96	0.200	15	ppb
249-1726-N/A-001-B	Classroom Sink Bubbler - Classroom 139	7/25/2018	7/31/2018	A8G0665-06	Copper	0.878	0.00200	1.3	ppm
249-1726-N/A-001-B	Classroom Sink Bubbler - Classroom 139	7/25/2018	8/1/2018	A8G0665-06RE1	Lead	1.64	0.200	15	ppb
249-1847-N/A-001-A	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	7/31/2018	A8G0665-07	Copper	0.676	0.00200	1.3	ppm
249-1847-N/A-001-A	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	8/1/2018	A8G0665-07RE1	Lead	14.2	0.200	15	ppb
249-1847-N/A-001-B	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	7/31/2018	A8G0665-08	Copper	0.639	0.00200	1.3	ppm
249-1847-N/A-001-B	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	8/2/2018	A8G0665-08RE1	Lead	1.97	0.200	15	ppb
249-1848-N/A-001-A	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	7/31/2018	A8G0665-09	Copper	0.474	0.00200	1.3	ppm
249-1848-N/A-001-A	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	8/2/2018	A8G0665-09RE1	Lead	1.81	0.200	15	ppb
249-1848-N/A-001-B	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	7/31/2018	A8G0665-10	Copper	0.397	0.00200	1.3	ppm
249-1848-N/A-001-B	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	8/2/2018	A8G0665-10RE1	Lead	0.884	0.200	15	ppb
249-1849-N/A-001-A	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	7/31/2018	A8G0665-11	Copper	0.551	0.00200	1.3	ppm
249-1849-N/A-001-A	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	8/3/2018	A8G0665-11RE2	Lead	5.77	2.00	15	ppb
249-1849-N/A-001-B	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	7/31/2018	A8G0665-12	Copper	0.532	0.00200	1.3	ppm

249-1849-N/A-001-B	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	8/2/2018	A8G0665-12RE1	Lead	1.23	0.200	15	ppb
249-1851-N/A-001-A	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	7/31/2018	A8G0665-13	Copper	0.758	0.00200	1.3	ppm
249-1851-N/A-001-A	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	8/2/2018	A8G0665-13RE1	Lead	0.842	0.200	15	ppb
249-1851-N/A-001-B	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	8/7/2018	A8G0665-14RE4	Copper	0.383	0.00200	1.3	ppm
249-1851-N/A-001-B	CTE Room Sink (CTE Faucet) - Classroom 224B	7/25/2018	8/7/2018	A8G0665-14RE4	Lead	1.00	0.200	15	ppb
249-1844-N/A-001-A	Classroom Sink Bubbler - Classroom 228	7/25/2018	8/1/2018	A8G0665-15RE1	Copper	1.08	0.0200	1.3	ppm
249-1844-N/A-001-A	Classroom Sink Bubbler - Classroom 228	7/25/2018	8/2/2018	A8G0665-15RE2	Lead	9.05	0.200	15	ppb
249-1844-N/A-001-B	Classroom Sink Bubbler - Classroom 228	7/25/2018	8/1/2018	A8G0665-16	Copper	0.365	0.00200	1.3	ppm
249-1844-N/A-001-B	Classroom Sink Bubbler - Classroom 228	7/25/2018	8/2/2018	A8G0665-16RE1	Lead	3.56	0.200	15	ppb
249-1842-N/A-001-A	Classroom Sink - Hallway (by 210C)	7/25/2018	8/1/2018	A8G0665-17RE1	Copper	0.994	0.0200	1.3	ppm
249-1842-N/A-001-A	Classroom Sink - Hallway (by 210C)	7/25/2018	8/2/2018	A8G0665-17RE2	Lead	5.50	0.200	15	ppb
249-1842-N/A-001-B	Classroom Sink - Hallway (by 210C)	7/25/2018	8/1/2018	A8G0665-18	Copper	0.779	0.00200	1.3	ppm
249-1842-N/A-001-B	Classroom Sink - Hallway (by 210C)	7/25/2018	8/2/2018	A8G0665-18RE1	Lead	2.23	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.