

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Beverly Cleary - Fernwood Elementary - 2nd Site Visit

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
249-1711-A-001-A	Food Prep Sprayer - Kitchen	8/28/2018	8/29/2018	A8H0775-01	Copper	0.101	0.00200	1.3	ppm
249-1711-A-001-A	Food Prep Sprayer - Kitchen	8/28/2018	8/29/2018	A8H0775-01	Lead	0.507	0.200	15	ppb
249-1711-A-001-B	Food Prep Sprayer - Kitchen	8/28/2018	8/29/2018	A8H0775-02	Copper	0.0446	0.00200	1.3	ppm
249-1711-A-001-B	Food Prep Sprayer - Kitchen	8/28/2018	8/29/2018	A8H0775-02	Lead	ND	0.200	15	ppb
249-1711-B-001-A	Food Prep Faucet - Kitchen	8/28/2018	8/29/2018	A8H0775-03	Copper	0.139	0.00200	1.3	ppm
249-1711-B-001-A	Food Prep Faucet - Kitchen	8/28/2018	8/29/2018	A8H0775-03	Lead	1.89	0.200	15	ppb
249-1711-B-001-B	Food Prep Faucet - Kitchen	8/28/2018	8/29/2018	A8H0775-04	Copper	0.0438	0.00200	1.3	ppm
249-1711-B-001-B	Food Prep Faucet - Kitchen	8/28/2018	8/29/2018	A8H0775-04	Lead	ND	0.200	15	ppb
249-9001-A-001-A	Drinking Fountain (Metal) Left - by Main Entrance	8/28/2018	8/29/2018	A8H0775-05	Copper	0.965	0.00200	1.3	ppm
249-9001-A-001-A	Drinking Fountain (Metal) Left - by Main Entrance	8/28/2018	8/29/2018	A8H0775-05	Lead	0.891	0.200	15	ppb
249-9001-A-001-B	Drinking Fountain (Metal) Left - by Main Entrance	8/28/2018	8/29/2018	A8H0775-06	Copper	0.830	0.00200	1.3	ppm
249-9001-A-001-B	Drinking Fountain (Metal) Left - by Main Entrance	8/28/2018	8/29/2018	A8H0775-06	Lead	0.332	0.200	15	ppb
249-9001-B-001-A	Drinking Fountain (Metal) Right - by Main Entrance	8/28/2018	8/29/2018	A8H0775-07	Copper	0.395	0.00200	1.3	ppm
249-9001-B-001-A	Drinking Fountain (Metal) Right - by Main Entrance	8/28/2018	8/29/2018	A8H0775-07	Lead	0.560	0.200	15	ppb
249-9001-B-001-B	Drinking Fountain (Metal) Right - by Main Entrance	8/28/2018	8/29/2018	A8H0775-08	Copper	0.230	0.00200	1.3	ppm
249-9001-B-001-B	Drinking Fountain (Metal) Right - by Main Entrance	8/28/2018	8/29/2018	A8H0775-08	Lead	0.200	0.200	15	ppb
249-9001-C-001-A	Bottle Fill (Haws Add-on) - by Main Entrance	8/28/2018	8/29/2018	A8H0775-09	Copper	0.176	0.00200	1.3	ppm
249-9001-C-001-A	Bottle Fill (Haws Add-on) - by Main Entrance	8/28/2018	8/29/2018	A8H0775-09	Lead	0.285	0.200	15	ppb
249-9001-C-001-B	Bottle Fill (Haws Add-on) - by Main Entrance	8/28/2018	8/29/2018	A8H0775-10	Copper	0.164	0.00200	1.3	ppm
249-9001-C-001-B	Bottle Fill (Haws Add-on) - by Main Entrance	8/28/2018	8/29/2018	A8H0775-10	Lead	ND	0.200	15	ppb
249-1846-N/A-001-A	CTE Room Sink Faucet - Classroom 224B	8/28/2018	8/29/2018	A8H0775-11	Copper	0.383	0.00200	1.3	ppm
249-1846-N/A-001-A	CTE Room Sink Faucet - Classroom 224B	8/28/2018	8/29/2018	A8H0775-11	Lead	7.65	0.200	15	ppb

249-1846-N/A-001-B	CTE Room Sink Faucet - Classroom 224B	8/28/2018	8/29/2018	A8H0775-12	Copper	0.495	0.00200	1.3	ppm
249-1846-N/A-001-B	CTE Room Sink Faucet - Classroom 224B	8/28/2018	8/29/2018	A8H0775-12	Lead	1.13	0.200	15	ppb
249-9002-A-001-A	Drinking Fountain (Metal) Left - Hallway by 221	8/28/2018	8/29/2018	A8H0775-13	Copper	0.634	0.00200	1.3	ppm
249-9002-A-001-A	Drinking Fountain (Metal) Left - Hallway by 221	8/28/2018	8/29/2018	A8H0775-13	Lead	1.04	0.200	15	ppb
249-9002-A-001-B	Drinking Fountain (Metal) Left - Hallway by 221	8/28/2018	8/29/2018	A8H0775-14	Copper	0.185	0.00200	1.3	ppm
249-9002-A-001-B	Drinking Fountain (Metal) Left - Hallway by 221	8/28/2018	8/29/2018	A8H0775-14	Lead	ND	0.200	15	ppb
249-9002-B-001-A	Drinking Fountain (Metal) Right - Hallway by 221	8/28/2018	8/29/2018	A8H0775-15	Copper	0.691	0.00200	1.3	ppm
249-9002-B-001-A	Drinking Fountain (Metal) Right - Hallway by 221	8/28/2018	8/29/2018	A8H0775-15	Lead	0.789	0.200	15	ppb
249-9002-B-001-B	Drinking Fountain (Metal) Right - Hallway by 221	8/28/2018	8/29/2018	A8H0775-16	Copper	0.177	0.00200	1.3	ppm
249-9002-B-001-B	Drinking Fountain (Metal) Right - Hallway by 221	8/28/2018	8/29/2018	A8H0775-16	Lead	0.233	0.200	15	ppb
249-9002-C-001-A	Bottle Fill (Haws Add-on) - Hallway by 221	8/28/2018	8/29/2018	A8H0775-17	Copper	0.134	0.00200	1.3	ppm
249-9002-C-001-A	Bottle Fill (Haws Add-on) - Hallway by 221	8/28/2018	8/29/2018	A8H0775-17	Lead	0.505	0.200	15	ppb
249-9002-C-001-B	Bottle Fill (Haws Add-on) - Hallway by 221	8/28/2018	8/29/2018	A8H0775-18	Copper	0.132	0.00200	1.3	ppm
249-9002-C-001-B	Bottle Fill (Haws Add-on) - Hallway by 221	8/28/2018	8/29/2018	A8H0775-18	Lead	ND	0.200	15	ppb
249-1843-N/A-001-A	Drinking Fountain (Metal) - Hallway by 220A/B	8/28/2018	8/29/2018	A8H0775-19	Copper	0.875	0.00200	1.3	ppm
249-1843-N/A-001-A	Drinking Fountain (Metal) - Hallway by 220A/B	8/28/2018	8/29/2018	A8H0775-19	Lead	5.74	0.200	15	ppb
249-1843-N/A-001-B	Drinking Fountain (Metal) - Hallway by 220A/B	8/28/2018	8/29/2018	A8H0775-20	Copper	0.664	0.00200	1.3	ppm
249-1843-N/A-001-B	Drinking Fountain (Metal) - Hallway by 220A/B	8/28/2018	8/29/2018	A8H0775-20	Lead	1.09	0.200	15	ppb