

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Beverly Cleary School at Fernwood - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
249-CH1845-N/A-005-A	Hallway (131)	4/26/2019	4/26/2019	A9D0923-01	Lead	0.795	0.20	15	ppb
249-CH9003-N/A-005-A	Classroom 224B	4/26/2019	4/26/2019	A9D0923-02	Lead	3.32	0.20	15	ppb