

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Beverly Cleary School at Hollyrood

Sample Identification #		Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
256-3865-A-001-A		Sink (Food Prep) - Classroom 3	8/14/2018	8/22/2018	A8H0387-01	Lead	4.65	0.200	15	ppb
256-3865-A-001-A		Sink (Food Prep) - Classroom 3	8/14/2018	8/23/2018	A8H0387-01RE1	Copper	0.0845	0.00200	1.3	ppm
256-3865-A-001-B		Sink (Food Prep) - Classroom 3	8/14/2018	8/22/2018	A8H0387-02	Lead	1.42	0.200	15	ppb
256-3865-A-001-B		Sink (Food Prep) - Classroom 3	8/14/2018	8/23/2018	A8H0387-02RE1	Copper	0.00947	0.00200	1.3	ppm
256-3865-B-001-A		Bubbler - Classroom 3	8/14/2018	8/22/2018	A8H0387-03	Lead	3.06	0.200	15	ppb
256-3865-B-001-A		Bubbler - Classroom 3	8/14/2018	8/23/2018	A8H0387-03RE1	Copper	0.0340	0.00200	1.3	ppm
256-3865-B-001-B		Bubbler - Classroom 3	8/14/2018	8/22/2018	A8H0387-04	Lead	1.10	0.200	15	ppb
256-3865-B-001-B		Bubbler - Classroom 3	8/14/2018	8/23/2018	A8H0387-04RE1	Copper	0.0108	0.00200	1.3	ppm
256-3868-N/A-001-A		Sink Bubbler - Classroom 2	8/14/2018	8/22/2018	A8H0387-05	Lead	15.3	0.200	15	ppb
256-3868-N/A-001-A		Sink Bubbler - Classroom 2	8/14/2018	8/23/2018	A8H0387-05RE1	Copper	0.0448	0.00200	1.3	ppm
256-3868-N/A-001-B		Sink Bubbler - Classroom 2	8/14/2018	8/22/2018	A8H0387-06	Lead	3.73	0.200	15	ppb
256-3868-N/A-001-B		Sink Bubbler - Classroom 2	8/14/2018	8/23/2018	A8H0387-06RE1	Copper	0.0392	0.00200	1.3	ppm
256-3879-N/A-001-A		Sink Bubbler - Classroom 9	8/14/2018	8/22/2018	A8H0387-07	Lead	11.7	0.200	15	ppb
256-3879-N/A-001-A		Sink Bubbler - Classroom 9	8/14/2018	8/23/2018	A8H0387-07RE1	Copper	0.0542	0.00200	1.3	ppm
256-3879-N/A-001-B		Sink Bubbler - Classroom 9	8/14/2018	8/22/2018	A8H0387-08	Lead	8.39	0.200	15	ppb
256-3879-N/A-001-B		Sink Bubbler - Classroom 9	8/14/2018	8/23/2018	A8H0387-08RE1	Copper	0.0107	0.00200	1.3	ppm
256-3882-N/A-001-A		Sink Bubbler - Classroom 8	8/14/2018	8/22/2018	A8H0387-09	Lead	12.5	0.200	15	ppb
256-3882-N/A-001-A		Sink Bubbler - Classroom 8	8/14/2018	8/23/2018	A8H0387-09RE1	Copper	0.242	0.00200	1.3	ppm
256-3882-N/A-001-B		Sink Bubbler - Classroom 8	8/14/2018	8/22/2018	A8H0387-10	Lead	4.35	0.200	15	ppb
256-3882-N/A-001-B		Sink Bubbler - Classroom 8	8/14/2018	8/23/2018	A8H0387-10RE1	Copper	0.0245	0.00200	1.3	ppm
256-3885-N/A-001-A		Sink Bubbler - Classroom 7	8/14/2018	8/22/2018	A8H0387-11	Lead	13.2	0.200	15	ppb
256-3885-N/A-001-A		Sink Bubbler - Classroom 7	8/14/2018	8/23/2018	A8H0387-11RE1	Copper	0.0630	0.00200	1.3	ppm
256-3885-N/A-001-B		Sink Bubbler - Classroom 7	8/14/2018	8/22/2018	A8H0387-12	Lead	6.21	0.200	15	ppb

256-3885-N/A-001-B	Sink Bubbler - Classroom 7	8/14/2018	8/23/2018	A8H0387-12RE1	Copper	0.0171	0.00200	1.3	ppm
256-3873-N/A-001-A	Sink Bubbler - Classroom 17	8/14/2018	8/22/2018	A8H0387-13	Lead	19.7	0.200	15	ppb
256-3873-N/A-001-A	Sink Bubbler - Classroom 17	8/14/2018	8/23/2018	A8H0387-13RE1	Copper	0.0236	0.00200	1.3	ppm
256-3873-N/A-001-B	Sink Bubbler - Classroom 17	8/14/2018	8/23/2018	A8H0387-14RE1	Lead	6.46	0.200	15	ppb
256-3873-N/A-001-B	Sink Bubbler - Classroom 17	8/14/2018	8/23/2018	A8H0387-14RE1	Copper	0.00731	0.00200	1.3	ppm
256-3870-N/A-001-A	Sink Bubbler - Classroom 18	8/14/2018	8/23/2018	A8H0387-15RE1	Lead	45.0	0.200	15	ppb
256-3870-N/A-001-A	Sink Bubbler - Classroom 18	8/14/2018	8/23/2018	A8H0387-15RE1	Copper	0.0825	0.00200	1.3	ppm
256-3870-N/A-001-B	Sink Bubbler - Classroom 18	8/14/2018	8/22/2018	A8H0387-16	Lead	6.08	0.200	15	ppb
256-3870-N/A-001-B	Sink Bubbler - Classroom 18	8/14/2018	8/23/2018	A8H0387-16RE1	Copper	0.0172	0.00200	1.3	ppm
256-3867-A-001-A	Sink (Food Prep) - Classroom 19	8/14/2018	8/22/2018	A8H0387-17	Lead	6.11	0.200	15	ppb
256-3867-A-001-A	Sink (Food Prep) - Classroom 19	8/14/2018	8/23/2018	A8H0387-17RE1	Copper	0.0406	0.00200	1.3	ppm
256-3867-A-001-B	Sink (Food Prep) - Classroom 19	8/14/2018	8/22/2018	A8H0387-18	Lead	1.82	0.200	15	ppb
256-3867-A-001-B	Sink (Food Prep) - Classroom 19	8/14/2018	8/23/2018	A8H0387-18RE1	Copper	0.00585	0.00200	1.3	ppm
256-3867-B-001-A	Sink Bubbler - Classroom 19	8/14/2018	8/22/2018	A8H0387-19	Lead	13.2	0.200	15	ppb
256-3867-B-001-A	Sink Bubbler - Classroom 19	8/14/2018	8/23/2018	A8H0387-19RE1	Copper	0.0384	0.00200	1.3	ppm
256-3867-B-001-B	Sink Bubbler - Classroom 19	8/14/2018	8/22/2018	A8H0387-20	Lead	3.69	0.200	15	ppb
256-3867-B-001-B	Sink Bubbler - Classroom 19	8/14/2018	8/23/2018	A8H0387-20RE1	Copper	0.00960	0.00200	1.3	ppm

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.