

**Portland Public Schools**  
**Lead and Copper Water Sampling Results**  
**Initial and Follow Up Flush Sample Data**  
**Rose City Park**

| Sample Identification # |  | Location                                            | Date Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|--|-----------------------------------------------------|----------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 278-Unk.-A-001-A        |  | ADA Drinking Fountain - Hallway Across from Library | 8/16/2018      | 8/25/2018     | A8H0451-01 | Copper  | 0.489   | 0.00200         | 1.3               | ppm   |
| 278-Unk.-A-001-A        |  | ADA Drinking Fountain - Hallway Across from Library | 8/16/2018      | 8/25/2018     | A8H0451-01 | Lead    | ND      | 0.200           | 15                | ppb   |
| 278-Unk.-A-001-B        |  | ADA Drinking Fountain - Hallway Across from Library | 8/16/2018      | 8/25/2018     | A8H0451-02 | Copper  | 0.439   | 0.00200         | 1.3               | ppm   |
| 278-Unk.-A-001-B        |  | ADA Drinking Fountain - Hallway Across from Library | 8/16/2018      | 8/25/2018     | A8H0451-02 | Lead    | ND      | 0.200           | 15                | ppb   |
| 278-Unk.-B-001-A        |  | ADA Drinking Fountain - Hallway Across from Library | 8/16/2018      | 8/25/2018     | A8H0451-03 | Copper  | 0.504   | 0.00200         | 1.3               | ppm   |
| 278-Unk.-B-001-A        |  | ADA Drinking Fountain - Hallway Across from Library | 8/16/2018      | 8/25/2018     | A8H0451-03 | Lead    | ND      | 0.200           | 15                | ppb   |
| 278-Unk.-B-001-B        |  | ADA Drinking Fountain - Hallway Across from Library | 8/16/2018      | 8/25/2018     | A8H0451-04 | Copper  | 0.393   | 0.00200         | 1.3               | ppm   |
| 278-Unk.-B-001-B        |  | ADA Drinking Fountain - Hallway Across from Library | 8/16/2018      | 8/25/2018     | A8H0451-04 | Lead    | ND      | 0.200           | 15                | ppb   |
| 278-4992-N/A-001-A      |  | Sink Bubbler - Classroom 115                        | 8/16/2018      | 8/25/2018     | A8H0451-05 | Copper  | 0.230   | 0.00200         | 1.3               | ppm   |
| 278-4992-N/A-001-A      |  | Sink Bubbler - Classroom 115                        | 8/16/2018      | 8/25/2018     | A8H0451-05 | Lead    | 37.5    | 0.200           | 15                | ppb   |
| 278-4992-N/A-001-B      |  | Sink Bubbler - Classroom 115                        | 8/16/2018      | 8/25/2018     | A8H0451-06 | Copper  | 0.555   | 0.00200         | 1.3               | ppm   |
| 278-4992-N/A-001-B      |  | Sink Bubbler - Classroom 115                        | 8/16/2018      | 8/25/2018     | A8H0451-06 | Lead    | 9.50    | 0.200           | 15                | ppb   |
| 278-4989-N/A-001-A      |  | Sink Bubbler - Classroom 116                        | 8/16/2018      | 8/25/2018     | A8H0451-07 | Copper  | 0.261   | 0.00200         | 1.3               | ppm   |
| 278-4989-N/A-001-A      |  | Sink Bubbler - Classroom 116                        | 8/16/2018      | 8/25/2018     | A8H0451-07 | Lead    | 23.5    | 0.200           | 15                | ppb   |
| 278-4989-N/A-001-B      |  | Sink Bubbler - Classroom 116                        | 8/16/2018      | 8/25/2018     | A8H0451-08 | Copper  | 0.563   | 0.00200         | 1.3               | ppm   |
| 278-4989-N/A-001-B      |  | Sink Bubbler - Classroom 116                        | 8/16/2018      | 8/25/2018     | A8H0451-08 | Lead    | 11.0    | 0.200           | 15                | ppb   |
| 278-Unk#2-N/A-001-A     |  | Sink Bubbler - Classroom 16                         | 8/16/2018      | 8/25/2018     | A8H0451-09 | Copper  | 0.707   | 0.00200         | 1.3               | ppm   |
| 278-Unk#2-N/A-001-A     |  | Sink Bubbler - Classroom 16                         | 8/16/2018      | 8/25/2018     | A8H0451-09 | Lead    | 24.2    | 0.200           | 15                | ppb   |
| 278-Unk#2-N/A-001-B     |  | Sink Bubbler - Classroom 16                         | 8/16/2018      | 8/25/2018     | A8H0451-10 | Copper  | 0.229   | 0.00200         | 1.3               | ppm   |
| 278-Unk#2-N/A-001-B     |  | Sink Bubbler - Classroom 16                         | 8/16/2018      | 8/25/2018     | A8H0451-10 | Lead    | 6.07    | 0.200           | 15                | ppb   |
| 278-4647-A-001-A        |  | Drinking Fountain (Porcelain) - Hallway near 17     | 8/16/2018      | 8/25/2018     | A8H0451-11 | Copper  | 0.0178  | 0.00200         | 1.3               | ppm   |
| 278-4647-A-001-A        |  | Drinking Fountain (Porcelain) - Hallway near 17     | 8/16/2018      | 8/25/2018     | A8H0451-11 | Lead    | 2.02    | 0.200           | 15                | ppb   |
| 278-4647-A-001-B        |  | Drinking Fountain (Porcelain) - Hallway near 17     | 8/16/2018      | 8/25/2018     | A8H0451-12 | Copper  | 0.0126  | 0.00200         | 1.3               | ppm   |

|                    |                                                 |           |           |            |        |         |         |     |     |
|--------------------|-------------------------------------------------|-----------|-----------|------------|--------|---------|---------|-----|-----|
| 278-4647-A-001-B   | Drinking Fountain (Porcelain) - Hallway near 17 | 8/16/2018 | 8/25/2018 | A8H0451-12 | Lead   | 1.82    | 0.200   | 15  | ppb |
| 278-4647-B-001-A   | Drinking Fountain (Porcelain) - Hallway near 17 | 8/16/2018 | 8/25/2018 | A8H0451-13 | Copper | 0.0167  | 0.00200 | 1.3 | ppm |
| 278-4647-B-001-A   | Drinking Fountain (Porcelain) - Hallway near 17 | 8/16/2018 | 8/25/2018 | A8H0451-13 | Lead   | 2.06    | 0.200   | 15  | ppb |
| 278-4647-B-001-B   | Drinking Fountain (Porcelain) - Hallway near 17 | 8/16/2018 | 8/25/2018 | A8H0451-14 | Copper | 0.0146  | 0.00200 | 1.3 | ppm |
| 278-4647-B-001-B   | Drinking Fountain (Porcelain) - Hallway near 17 | 8/16/2018 | 8/25/2018 | A8H0451-14 | Lead   | 1.96    | 0.200   | 15  | ppb |
| 278-4651-N/A-001-A | Sink (Food Prep) - Kitchen                      | 8/16/2018 | 8/25/2018 | A8H0451-15 | Copper | 0.168   | 0.00200 | 1.3 | ppm |
| 278-4651-N/A-001-A | Sink (Food Prep) - Kitchen                      | 8/16/2018 | 8/25/2018 | A8H0451-15 | Lead   | 2.79    | 0.200   | 15  | ppb |
| 278-4651-N/A-001-B | Sink (Food Prep) - Kitchen                      | 8/16/2018 | 8/25/2018 | A8H0451-16 | Copper | 0.308   | 0.00200 | 1.3 | ppm |
| 278-4651-N/A-001-B | Sink (Food Prep) - Kitchen                      | 8/16/2018 | 8/25/2018 | A8H0451-16 | Lead   | 0.269   | 0.200   | 15  | ppb |
| 278-4652-N/A-001-A | Sprayer (Food Prep) - Kitchen                   | 8/16/2018 | 8/25/2018 | A8H0451-17 | Copper | 0.263   | 0.00200 | 1.3 | ppm |
| 278-4652-N/A-001-A | Sprayer (Food Prep) - Kitchen                   | 8/16/2018 | 8/25/2018 | A8H0451-17 | Lead   | 2.17    | 0.200   | 15  | ppb |
| 278-4652-N/A-001-B | Sprayer (Food Prep) - Kitchen                   | 8/16/2018 | 8/25/2018 | A8H0451-18 | Copper | 0.322   | 0.00200 | 1.3 | ppm |
| 278-4652-N/A-001-B | Sprayer (Food Prep) - Kitchen                   | 8/16/2018 | 8/25/2018 | A8H0451-18 | Lead   | 0.265   | 0.200   | 15  | ppb |
| 278-4996-A-001-A   | Drinking Fountain (Porcelain) - Hallway near 8  | 8/16/2018 | 8/25/2018 | A8H0451-19 | Copper | 0.00527 | 0.00200 | 1.3 | ppm |
| 278-4996-A-001-A   | Drinking Fountain (Porcelain) - Hallway near 8  | 8/16/2018 | 8/25/2018 | A8H0451-19 | Lead   | 1.53    | 0.200   | 15  | ppb |
| 278-4996-A-001-B   | Drinking Fountain (Porcelain) - Hallway near 8  | 8/16/2018 | 8/25/2018 | A8H0451-20 | Copper | 0.00231 | 0.00200 | 1.3 | ppm |
| 278-4996-A-001-B   | Drinking Fountain (Porcelain) - Hallway near 8  | 8/16/2018 | 8/25/2018 | A8H0451-20 | Lead   | 0.497   | 0.200   | 15  | ppb |
| 278-4996-B-001-A   | Drinking Fountain (Porcelain) - Hallway near 8  | 8/16/2018 | 8/25/2018 | A8H0451-21 | Copper | 0.00331 | 0.00200 | 1.3 | ppm |
| 278-4996-B-001-A   | Drinking Fountain (Porcelain) - Hallway near 8  | 8/16/2018 | 8/25/2018 | A8H0451-21 | Lead   | 2.05    | 0.200   | 15  | ppb |
| 278-4996-B-001-B   | Drinking Fountain (Porcelain) - Hallway near 8  | 8/16/2018 | 8/25/2018 | A8H0451-22 | Copper | ND      | 0.00200 | 1.3 | ppm |
| 278-4996-B-001-B   | Drinking Fountain (Porcelain) - Hallway near 8  | 8/16/2018 | 8/25/2018 | A8H0451-22 | Lead   | 0.928   | 0.200   | 15  | ppb |

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.